

**GOVERNMENT OF GOA**  
**WATER RESOURCES DEPARTMENT**  
**S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY**  
**Gogol - Margao - Goa.**

No. WRD / WD XI / SDIII / F.59 /WF.146/2021 /07 / 2022-23.

dated: 22-08-2022

Name of the Work: Construction of centre of excellence building for W.R.D. at WRD complex Gogol- Margao under NHP  
in the state of Goa.

Sample Sent by: Assistant Engineer, SD III , WD III, WRD, Gogol- Margao -Goa

Letter No: 253/SD III/ WD III/ WRD/2022-23/192.

Dated:- 12-08-2022.

Received on: 12-08-2022.

Date of Testing 16-08-2022

**REPORT**

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.146/01/2021	River Sand	FM Silt & Clay Grading	2.138 3.00% ...	2.3 to 3.1 Upto 5% Zone I to III	

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD III, WD III , WRD, Gogol- Margao-Goa.
- 2) The Executive Engineer, Works Division III, WRD, Ponda- Goa.
- 3) Executive Engineer, WD XI, WRD,Rawanfond-Goa.
- 4) Office File.