

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / TECH / WF. 96 -Oct-2022 /110 /2023-24.

Dated:12/05/2023

Name of the Work: Improvement of nallah near Antonio Pobrina Dias e Faleiro house at Aquem Baixo in Margao Constituency.

Sample Sent by: Assistant Engineer , SD III, WD III , WRD , Gogol - Margao - Goa.

Letter No: 322/SD III/WD III/WRD/23-24/54

Dated:- 4/5/2023

Received on: 10/5/2023

Date of Testing 12/5/2023

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.96/01/2022	Coarse Sand	FM Silt & Clay Grading	2.664 2.80% Zone III	2.3 to 3.1 Upto 5% I to III Zone	
F.96/02/2022	Metel Sand	FM Silt & Clay Grading	2.612 1.60% Zone II	2.3 to 3.1 Upto 5% I to III Zone	
F.96/03/2022	Aggregate-20 mm	Grading		As per IS-383:2016	To get the 20mm graded aggregate nominal size blend
F.96/04/2022	Aggregate- 10 mm	Grading		As per IS-383:2016	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

- Copy submitted to
- 1) Assistant Engineer, SD III, WD III, WRD, Gogol- Margao- Goa.
 - 2) The Executive Engineer, Works Division III, WRD, Ponda- Goa.
 - 3) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
 - 4) The Surveyor of Works,Quality Control, C.P.O.,Water Resources Dept., Sinchai Bhavan,Alto Porvorim-Goa.
 - 5) Office File.