

NO.WRD/WDXI/SDIII/TECH/W.F.28/2022/2022-23/118

. Dated:-04/02/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement & Development of bund in Sy.No. 33/1 at Orlim in Benaulim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.28/05/2022						226.67		No. WRD/SD I/WD II/
	F.28/06/2022	22-12-2022	19-01-2023	Foundation	1.2.4	210 kg/cm2	231.11	228.15	F.Esst/579/2022-23.
	F.28/07/2022						226.67		DATED: 29-12-2022.
1.2	F.28/08/2022						231.11		
	F.28/09/2022	22-12-2022	19-01-2023	Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.28/10/2022						222.22		
2.1	F.28/11/2022						235.56		
	F.28/12/2022	23-12-2022	20-01-2023	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.28/13/2022						226.67		
2.2	F.28/14/2022						235.56		
	F.28/09/2022	23-12-2022	20-01-2023	Foundation	1.2.4	210 kg/cm2	231.11	232.59	do
	F.28/10/2022						231.11		
3.1	F.28/11/2022						226.67		
	F.28/12/2022	24-12-2022	21-01-2023	Coping , Band	1.2.4	210 kg/cm2	217.78	222.22	do
	F.28/13/2022						222.22		
3.2	F.28/14/2022						217.78		
	F.28/15/2022	24-12-2022	21-01-2023	Coping , Band	1.2.4	210 kg/cm2	217.78	219.26	do
	F.28/16/2022						222.22		
4.1	F.28/17/2022						226.67		
	F.28/18/2022	26-12-2022	23-12-2023	Coping , Band	1.2.4	210 kg/cm2	213.33	222.22	do
	F.28/19/2022						226.67		
4.2	F.28/20/2022						226.67		
	F.28/21/2022	26-12-2022	23-12-2023	Coping , Band	1.2.4	210 kg/cm2	217.78	220.74	do
	F.28/22/2022						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER