

NO.WRD/WDXI/SDIII/TECH/W.F.83/2022/2022-23/120

. Dated:-22/05/2023

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to the nallah at Modi in Sy. No. 52/4 in V.P. Navelim in Navelim Constituency

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.83/06/2022						231.11		No. WRD/SD I/WD II/
	F.83/07/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	235.56	232.59	F.Estt/ 72 /23-24.
	F.83/08/2022						231.11		DATED: 02-05-2023
1.2	F.83/09/2022						240.00		
	F.83/10/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.83/11/2022						222.22		
1.3	F.83/12/2022						235.56		
	F.83/13/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	231.11	234.08	do
	F.83/14/2022						235.56		
1.4	F.83/15/2022						226.67		
	F.83/16/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.83/17/2022						231.11		
2.1	F.83/18/2022						222.22		
	F.83/19/2022	18/04/2023	16-05-2023	Foundation & Wall	1.2.4	210 kg/cm2	235.56	229.63	do
	F.83/20/2022						231.11		
2.2	F.83/21/2022						235.56		
	F.83/22/2022	18/04/2023	16-05-2023	Foundation & Wall	1.2.4	210 kg/cm2	217.78	231.11	do
	F.83/23/2022						240.00		
2.3	F.83/24/2022						231.11		
	F.83/25/2022	18/04/2023	16-05-2023	Foundation & Wall	1.2.4	210 kg/cm2	222.22	226.67	do
	F.83/26/2022						226.67		
2.4	F.83/27/2022						231.11		
	F.83/28/2022	18/04/2023	16-05-2023	Foundation & Wall	1.2.4	210 kg/cm2	235.56	231.11	do
	F.83/29/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the nallah at Modi in Sy. No. 52/4 in V.P. Navelim in Navelim Constituency

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.83/30/2022						240.00		No. WRD/SD I/WD II/
	F.83/31/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	231.11	234.07	F.Esst/72/2023-24.
	F.83/32/2022						231.11		DATED: 02-05-2023
3.2	F.83/33/2022						226.67		
	F.83/34/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	235.56	231.11	do
	F.83/35/2022						231.11		
3.3	F.83/36/2022						244.44		
	F.83/37/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	231.11	235.55	do
	F.83/38/2022						231.11		
3.4	F.83/39/2022						235.56		
	F.83/40/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	222.22	229.63	do
	F.83/41/2022						231.11		
4.1	F.83/42/2022						226.67		
	F.83/43/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	222.22	225.19	do
	F.83/44/2022						226.67		
4.2	F.83/45/2022						231.11		
	F.83/46/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	226.67	228.15	do
	F.83/47/2022						226.67		
4.3	F.83/48/2022						231.11		
	F.83/49/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	235.56	231.11	do
	F.83/50/2022						226.67		
4.4	F.83/51/2022						226.67		
	F.83/52/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.83/53/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the nallah at Modi in Sy. No. 52/4 in V.P. Navelim in Navelim Constituency

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.83/54/2022						231.11		No. WRD/SD I/WD II/
	F.83/55/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	222.22	228.15	F.Esst/72/2023-24.
	F.83/56/2022						231.11		DATED: 02-05-2023
5.2	F.83/57/2022						235.56		
	F.83/58/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	226.67	231.11	do
	F.83/59/2022						231.11		
5.3	F.83/60/2022						235.56		
	F.83/61/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	240.00	232.59	do
	F.83/62/2022						222.22		
5.4	F.83/63/2022						217.78		
	F.83/64/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	240.00	231.11	do
	F.83/65/2022						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER