

NO.WRD/WDXI/SDIII/TECH/W.F.84/2022/2023-24/121

. Dated:-22/05/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah in Sy. No. 43/0 near Dharm Prabhu house house in V.P. Aquem Baixo in Navelim Constituency

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.84/06/2022						226.67		No. WRD/SD I/WD II/
	F.84/07/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	235.56	231.11	F.Estt/ 71 /23-24.
	F.84/08/2022						231.11		DATED: 02-05-2023
1.2	F.84/09/2022						231.11		
	F.84/10/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.84/11/2022						222.22		
1.3	F.84/12/2022						235.56		
	F.84/13/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	226.67	232.60	do
	F.84/14/2022						235.56		
1.4	F.84/15/2022						231.11		
	F.84/16/2022	17/04/2023	15-05-2023	Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.84/17/2022						226.67		
2.1	F.84/18/2022						235.56		
	F.84/19/2022	18/04/2023	16-05-2023	Foundation	1.2.4	210 kg/cm2	240.00	234.08	do
	F.84/20/2022						226.67		
2.2	F.84/21/2022						231.11		
	F.84/22/2022	18/04/2023	16-05-2023	Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.84/23/2022						231.11		
2.3	F.84/24/2022						244.44		
	F.84/25/2022	18/04/2023	16-05-2023	Foundation	1.2.4	210 kg/cm2	231.11	235.55	do
	F.84/26/2022						231.11		
2.4	F.84/27/2022						235.56		
	F.84/28/2022	18/04/2023	16-05-2023	Foundation	1.2.4	210 kg/cm2	240.00	235.56	do
	F.84/29/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement of nallah in Sy. No. 43/0 near Dharm Prabhu house house in V.P. Aquem Baixo in Navelim Constituency

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.84/30/2022						231.11		No. WRD/SD I/WD II/
	F.84/31/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	235.56	228.15	F.Estt/71/23-24.
	F.84/32/2022						217.78		DATED: 02-05-2023
3.2	F.84/33/2022						235.56		
	F.84/34/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	226.67	231.11	do
	F.84/35/2022						231.11		
3.3	F.84/36/2022						240.00		
	F.84/37/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	222.22	235.55	do
	F.84/38/2022						244.44		
3.4	F.84/39/2022						235.56		
	F.84/40/2022	19/04/2023	17-05-2023	Foundation & wall	1.2.4	210 kg/cm2	235.56	234.08	do
	F.84/41/2022						231.11		
4.1	F.84/42/2022						226.67		
	F.84/43/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	222.22	228.15	do
	F.84/44/2022						235.56		
4.2	F.84/45/2022						235.56		
	F.84/46/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	235.56	228.15	do
	F.84/47/2022						213.33		
4.3	F.84/48/2022						231.11		
	F.84/49/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.84/50/2022						222.22		
4.3	F.84/51/2022						231.11		
	F.84/52/2022	20/04/2023	18-05-2023	wall	1.2.4	210 kg/cm2	231.11	229.63	do
	F.84/53/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah in Sy. No. 43/0 near Dharm Prabhu house house in V.P. Aquem Baixo in Navelim Constituency

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.84/54/2022						231.11		No. WRD/SD I/WD II/
	F.84/55/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	231.11	228.15	F.Estt/ 71 /23-24.
	F.84/56/2022						222.22		DATED: 02-05-2023
5.2	F.84/57/2022						235.56		
	F.84/58/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	226.67	231.11	do
	F.84/59/2022						231.11		
5.3	F.84/60/2022						222.22		
	F.84/61/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	235.56	225.19	do
	F.84/62/2022						217.78		
5.4	F.84/63/2022						231.11		
	F.84/64/2022	21/04/2023	19-05-2023	wall	1.2.4	210 kg/cm2	231.11	229.63	do
	F.84/65/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER