

NO.WRD/WDXI/SDIII/TECH/W.F.14/2022/2022-23/125

. Dated:-04/02/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protective bund on the bank of Sal river at Dongrim in Village Majorda in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.14/05/2022						222.22		No. WRD/SD I/WD II/
	F.14/06/2022	21-12-2022	18-01-2023	Foundation	1.2.4	210 kg/cm2	231.11	226.67	F.Esst/ 580 /22-23.
	F.14/07/2022						226.67		DATED: 29-12-2022.
1.2	F.14/08/2022						231.11		
	F.14/09/2022	21-12-2022	18-01-2023	Foundation	1.2.4	210 kg/cm2	222.22	225.18	do
	F.14/10/2022						222.22		
2.1	F.14/11/2022						226.67		
	F.14/12/2022	23-12-2022	20-01-2023	Foundation	1.2.4	210 kg/cm2	217.78	225.19	do
	F.14/13/2022						231.11		
2.2	F.14/14/2022						226.67		
	F.14/09/2022	23-12-2022	20-01-2023	Foundation	1.2.4	210 kg/cm2	231.11	226.67	do
	F.14/10/2022						222.22		
2.3	F.14/11/2022						226.67		
	F.14/12/2022	23-12-2022	20-01-2023	Foundation	1.2.4	210 kg/cm2	226.67	225.19	do
	F.14/13/2022						222.22		
3.1	F.14/14/2022						222.22		
	F.14/15/2022	24-12-2022	21-01-2023	Aprons	1.2.4	210 kg/cm2	217.78	222.22	do
	F.14/16/2022						226.67		
3.2	F.14/17/2022						222.22		
	F.14/18/2022	24-12-2022	21-01-2023	Aprons	1.2.4	210 kg/cm2	213.33	220.74	do
	F.14/19/2022						226.67		
3.3	F.14/20/2022						226.67		
	F.14/21/2022	24-12-2022	21-01-2023	Aprons	1.2.4	210 kg/cm2	217.78	222.22	do
	F.14/22/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protective bund of the bank of Sal river at Dongrim in Village Majorda in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.14/23/2022						231.11		No. WRD/SD I/WD II/ F.Estt/ 580 /2022-23. DATED: 29-12-2022.
	F.14/24/2022	26-12-2022	23-01-2023	Aprons	1.2.4	210 kg/cm2	226.67	231.11	
	F.14/25/2022						235.56		
4.2	F.14/26/2022						226.67		
	F.14/27/2022	26-12-2022	23-01-2023	Aprons	1.2.4	210 kg/cm2	231.11	229.63	do
	F.14/28/2022						231.11		
5.1	F.14/29/2022						226.67		
	F.14/30/2022	28-12-2022	25-01-2023	Wall	1.2.4	210 kg/cm2	213.33	222.22	do
	F.14/31/2022						226.67		
5.2	F.14/32/2022						226.67		
	F.14/33/2022	28-12-2022	25-01-2023	Wall	1.2.4	210 kg/cm2	222.22	226.67	do
	F.14/34/2022						231.11		
5.3	F.14/35/2022						217.78		
	F.14/36/2022	28-12-2022	25-01-2023	Wall	1.2.4	210 kg/cm2	222.22	222.22	do
	F.14/37/2022						226.67		
5.4	F.14/38/2022						231.11		
	F.14/39/2022	28-12-2022	25-01-2023	Wall	1.2.4	210 kg/cm2	226.67	225.19	do
	F.14/40/2022						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER