

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / F.59 /WF.147/2021 / 13 / 2022-23.

dated: **06-10-2022**

Name of the Work: Construction of box conduit for paroda canal from Ch.300m to 550 m in front of Quepem municipal Council and further from 727 mts to 847 mts and its allied works for Paroda canal in Quepem Taluka.

Sample Sent by: Assistant Engineer, SD I , WD II, WRD, Rawanfond -Goa

Letter No: NO. WRD/SD I/ WD II/F.Estt/641/2022-23.

Dated:- 21-04-2022.

Received on: 19-08-2022

Date of Testing 23-08-2022

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.147/01/2021	Coarse Sand	FM Silt & Clay Grading	2.618 1.60% Zone II	2.3 to 3.1 Upto 5% I to III Zone	
F.147/02/2021	Aggregate-20 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	To get the 20mm graded aggregate nominal size blend
F.147/03/2021	Aggregate- 10 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD I, WD II, WRD, Rawanfond-Goa.
- 2) The Executive Engineer, Works Division II, WRD, Rawanfond- Goa.
- 3) Executive Engineer, WD XI, WRD, Rawanfond-Goa.
- 4) Office File.