

NO.WRD/WDXI/SDIII/TECH/W.F.30/2022/2022-23/ 33

. Dated:-16/02/2023

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to bank protection for nallah in Sy.No. 112/1 to 112/3 at Chicalim Village in Dabolim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.30/05/2022						231.11		No. WRD/SD II/WD II/
	F.30/06/2022	13-01-2023	10/2/2023	Wall Foundation	1.2.4	210 kg/cm2	226.67	228.15	F.03/ 223 /2022-23.
	F.30/07/2022						226.67		DATED: 23-01-2023.
1.2	F.30/08/2022						226.67		
	F.30/09/2022	13-01-2023	10/2/2023	Wall Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.30/10/2022						235.56		
1.3	F.30/11/2022						231.11		
	F.30/12/2022	13-01-2023	10/2/2023	Wall Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.30/13/2022						226.67		
1.4	F.30/14/2022						226.67		
	F.30/09/2022	13-01-2023	10/2/2023	Wall Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.30/10/2022						231.11		
2.1	F.30/11/2022						226.67		
	F.30/12/2022	14-01-2023	11/2/2023	Wall Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.30/13/2022						231.11		
2.2	F.30/14/2022						226.67		
	F.30/15/2022	14-01-2023	11/2/2023	Wall Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.30/16/2022						226.67		
2.3	F.30/17/2022						226.67		
	F.30/18/2022	14-01-2023	11/2/2023	Wall Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.30/19/2022						226.67		
2.4	F.30/20/2022						231.11		
	F.30/21/2022	14-01-2023	11/2/2023	Wall Foundation	1.2.4	210 kg/cm2	222.22	225.18	do
	F.30/22/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to bank protection for nallah in Sy.No. 112/1 to 112/3 at Chicalim Village in Dabolim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.30/23/2022						226.67		No. WRD/SD II/WD II/
	F.30/24/2022	16-01-2023	13-02-2023	Wall above Foundation 1st Lift	1.2.4	210 kg/cm2	222.22	222.22	F.03/ 223 /2022-23.
	F.30/25/2022						217.78		DATED: 23-01-2023.
3.2	F.30/26/2022						222.22		
	F.30/27/2022	16-01-2023	13-02-2023	Wall above Foundation 1st Lift	1.2.4	210 kg/cm2	222.22	223.70	do
	F.30/28/2022						226.67		
3.3	F.30/29/2022						217.78		
	F.30/30/2022	16-01-2023	13-02-2023	Wall above Foundation 1st Lift	1.2.4	210 kg/cm2	226.67	223.71	do
	F.30/31/2022						226.67		
3.4	F.30/32/2022						226.67		
	F.30/33/2022	16-01-2023	13-02-2023	Wall above Foundation 1st Lift	1.2.4	210 kg/cm2	222.22	222.22	do
	F.30/34/2022						217.78		
4.1	F.30/35/2022						226.67		
	F.30/36/2022	18-01-2023	15-02-2023	Wall above Foundation 2nd Lift	1.2.4	210 kg/cm2	231.11	225.19	do
	F.30/37/2022						217.78		
4.2	F.30/38/2022						222.22		
	F.30/39/2022	18-01-2023	15-02-2023	Wall above Foundation 2nd Lift	1.2.4	210 kg/cm2	213.33	220.74	do
	F.30/40/2022						226.67		
4.3	F.30/41/2022						231.11		
	F.30/42/2022	18-01-2023	15-02-2023	Wall above Foundation 2nd Lift	1.2.4	210 kg/cm2	222.22	225.18	do
	F.30/43/2022						222.22		
4.4	F.30/44/2022						226.67		
	F.30/45/2022	18-01-2023	15-02-2023	Wall above Foundation 2nd Lift	1.2.4	210 kg/cm2	226.67	225.19	do
	F.30/46/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to bank protection for nallah in Sy.No. 112/1 to 112/3 at Chicalim Village in Dabolim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.30/47/2022						226.67		No. WRD/SD II/WD II/
	F.30/48/2022	19-01-2023	16-02-2023	Wall above Foundation 3rd Lift	1.2.4	210 kg/cm2	235.56	228.15	F.03/ 223 /2022-23.
	F.30/49/2022						222.22		DATED: 23-01-2023.
5.2	F.30/50/2022						226.67		
	F.30/51/2022	19-01-2023	16-02-2023	Wall above Foundation 3rd Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.30/52/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER