

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / TECH / WF.No. 99-Oct-2022 /148 / 2023-24.

dated:20/06/2023

Name of the Work: Construction of retaining wall for the nallah in Sy.No. 192/14 at Verna in Nuvem Constituency of Salcete Taluka.

Sample Sent by: Assistant Engineer, SD I , WD II, WRD, Rawanfond -Goa

Letter No: No.WRD/SDI/WDII/F.Esst/249/23-24.

Dated:- 9/6/2023

Received on: 9/6/2023

Date of Testing 9/6/2023

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.99/01/2022	Coarse Sand	FM Silt & Clay Grading	2.516 2.00% Zone III	2.3 to 3.1 Upto 5% I to III Zone	
F.99/02/2022	Aggregate-20 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	To get the 20mm graded aggregate nominal size blend
F.99/03/2022	Aggregate- 10 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD I, WD II, WRD, Rawanfond -Goa.
- 2) The Executive Engineer, Works Division II, WRD, Rawanfond Goa.
- 3) Executive Engineer, WD XI, WRD, Rawanfond-Goa.
- 4) The Surveyor of Works, Quality Control, C.P.O., Water Resources Dept., Sinchai Bhavan, Alto Porvorim-Goa.
- 5) Office File.