

NO.WRD/WDXI/SDIII/TECH/W.F.151/2021/2022-23/20

. Dated:-28-10-2022

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Repairs to Irrigation Tank in Sy.No. 95/1 at Bagwada, Manmollem in V.P. Betqui, Candola in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.151/05/2021						155.56		No. WRD/WD XI/SD IV/
	F.151/06/2021	29-09-2022	6/10/2022	For Foundation	1.2.4	140 kg/cm2	160.00	158.52	F. CF/292/2022-23.
	F.151/07/2021						160.00		DATED: 30-09-2022.
2	F.151/08/2021						160.00		
	F.151/09/2021	30-09-2022	7/10/2022	For Foundation	1.2.4	140 kg/cm2	155.56	160.00	do
	F.151/10/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER