

NO.WRD/WDXI/SDIII/TECH/W.F.151/2021/2022-23/20

. Dated:-28/10/2022

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Repairs to Irrigation Tank in Sy.No. 95/1 at Bagwada, Manmollem in V.P. Betqui, Candola in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.151/11/2021						213.33		No. WRD/WD XI/SD IV/
	F.151/12/2021	29-09-2022	27-10-2022	For Foundation	1.2.4	210 kg/cm2	217.78	216.30	F. CF/292/2022-23.
	F.151/13/2021						217.78		DATED: 30-09-2022.
2	F.151/14/2021						222.22		
	F.151/15/2021	30-09-2022	28-10-2022	For Foundation	1.2.4	210 kg/cm2	222.22	220.74	do
	F.151/16/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER