

NO.WRD/WDXI/SDIII/TECH/W.F.06/2024/2024-25/200

. Dated:-

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent protection for nallah near the house of Dattatray Devari at Deulwada in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.06/06/2024						151.11		No. WRD/WD XI/ SD IV/ W.F 495/ 415 /2024-25. DATED: 14-11-2024.
	F.06/07/2024	7/11/2024	14-11-2024	Foundation	1.2.4	140 kg/cm2	146.67	146.67	
	F.06/08/2024						142.22		
1.2	F.06/09/2024						151.11		
	F.06/10/2024	7/11/2024	14-11-2024	Foundation	1.2.4	140 kg/cm2	146.67	148.15	do
	F.06/11/2024						146.67		
2.1	F.06/12/2024						155.56		
	F.06/13/2024	8/11/2024	15-11-2024	Foundation	1.2.4	140 kg/cm2	142.22	146.67	do
	F.06/14/2024						142.22		
2.2	F.06/15/2024						151.11		
	F.06/16/2024	8/11/2024	15-11-2024	Foundation	1.2.4	140 kg/cm2	142.22	145.18	do
	F.06/17/2024						142.22		
3.1	F.06/18/2024						151.11		
	F.06/19/2024	10/11/2024	18-11-2024	1st Lift	1.2.4	140 kg/cm2	151.11	148.15	do
	F.06/20/2024						142.22		
3.2	F.06/21/2024						155.56		
	F.06/22/2024	10/11/2024	18-11-2024	1st Lift	1.2.4	140 kg/cm2	151.11	149.63	do
	F.06/23/2024						142.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent protection for nallah near the house of Dattatray Devari at Deulwada in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.06/24/2024						151.11		No. WRD/WD XI/ SD IV/ W.F 495/ 415 /2024-25. DATED: 14-11-2024.
	F.06/25/2024	11/11/2024	18-11-2024	1st Lift	1.2.4	140 kg/cm2	151.11	146.67	
	F.06/26/2024						137.78		
4.2	F.06/27/2024						160.00		
	F.06/28/2024	11/11/2024	18-11-2024	1st Lift	1.2.4	140 kg/cm2	142.22	148.15	do
	F.06/29/2024						142.22		
5.1	F.06/30/2024						151.11		
	F.06/31/2024	13-11-2024	20-11-2024	2nd Lift	1.2.4	140 kg/cm2	146.67	145.19	do
	F.06/32/2024						137.78		
5.2	F.06/33/2024						155.56		
	F.06/34/2024	13-11-2024	20-11-2024	2nd Lift	1.2.4	140 kg/cm2	142.22	146.67	do
	F.06/35/2024						142.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER