

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing random rubble masonry and other works connecting 2 No. CD's between Ch. 9.80 km to Ch. 10.00 Km of SIP canal.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.40/06/2024						75.56		No. WRD/WD X/ SD I/
	F.40/07/2024	10/12/2024	17-12-2024	All works upto plinth level	1.3.6	70 kg/cm2	84.44	77.04	F. 55A/ 190 /2024-25.
	F.40/08/2024						71.11		DATED: 12-12-2024.
2	F.40/09/2024						80.00		
	F.40/10/2024	11/12/2024	18-12-2024	All works upto plinth level	1.3.6	70 kg/cm2	84.44	78.52	
	F.40/11/2024						71.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER