

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of protection wall to intake chamber at L.I.Scheme Potrem V.P. Bhati in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.17/06/2024						231.11		No. WRD/SD I/ WD XII/
	F.17/07/2024	12/11/2024	10/12/2024	Pump house from side ch.	1.2.4	210 kg/cm2	226.67	228.15	F. 47/260/2024-25.
	F.17/08/2024			0.00 m to 5.00 m			226.67		DATED: 22-11-2024
2	F.17/09/2024						235.56		
	F.17/10/2024	12/11/2024	10/12/2024	Pump house from side ch.	1.2.4	210 kg/cm2	231.11	229.63	do
	F.17/11/2024			5.00 m to 10.00 m			222.22		
3	F.17/12/2024						235.56		
	F.17/13/2024	14-11-2024	12/12/2024	1st Lift front side Ch.	1.2.4	210 kg/cm2	222.22	225.19	do
	F.17/14/2024			0.00m to 10.00m			217.78		
4	F.17/15/2024						231.11		
	F.17/16/2024	16-11-2024	16-12-2024	2nd Lift front side Ch.	1.2.4	210 kg/cm2	222.22	226.67	do
	F.17/17/2024			0.00m to 10.00m			226.67		
5	F.17/18/2024						231.11		
	F.17/19/2024	16-11-2024	16-12-2024	Pump house back side	1.2.4	210 kg/cm2	231.11	228.15	do
	F.17/20/2024			0.00m to 5.00m			222.22		
6	F.17/21/2024						235.56		
	F.17/22/2024	18-11-2024	16-12-2024	3rd Lift front side Ch.	1.2.4	210 kg/cm2	226.67	226.67	do
	F.17/23/2024			0.00m to 10.00m			217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of protection wall to intake chamber at L.I.Scheme Potrem V.P. Bhati in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7	F.17/24/2024						235.56		No. WRD/SD I/ WD XII/
	F.17/25/2024	18-11-2024	16-12-2024	1st Lift back side Ch.	1.2.4	210 kg/cm2	226.67	228.15	F. 47/ 260 /2024-25.
	F.17/26/2024			0.00m to 5.00m			222.22		DATED: 22-11-2024
8	F.17/27/2024						231.11		
	F.17/28/2024	19-11-2024	17-12-2024	2nd Lift back side Ch.	1.2.4	210 kg/cm2	231.11	226.67	do
	F.17/29/2024			0.00m to 5.00m			217.78		
9	F.17/30/2024						235.56		
	F.17/31/2024	20-11-2024	18-12-2024	3rd Lift back side Ch.	1.2.4	210 kg/cm2	226.67	225.19	do
	F.17/32/2024			0.00m to 5.00m			213.33		
10	F.17/33/2024						231.31		
	F.17/34/2024	21-11-2024	20-12-2024	4th Lift back side Ch.	1.2.4	210 kg/cm2	231.11	228.21	do
	F.17/35/2024			0.00m to 5.00m			222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER