

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of existing protection wall along the field side at Agalli in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.18/05/2024						231.11		No. 356/ SD III/ WD III/ WRD/24-25/ 304 DATED: 29-11-2024
	F.18/06/2024	13-11-2024	11/12/2024	Base 1	1.2.4	210 kg/cm2	226.67	226.67	
	F.18/07/2024						222.22		
1.2	F.18/08/2024						231.11		
	F.18/09/2024	13-11-2024	11/12/2024	Base 1	1.2.4	210 kg/cm2	217.78	223.70	do
	F.18/10/2024						222.22		
2.1	F.18/11/2024						235.56		
	F.18/12/2024	16-11-2024	16-12-2024	Base 2	1.2.4	210 kg/cm2	226.67	228.15	do
	F.18/13/2024						222.22		
2.2	F.18/14/2024						231.11		
	F.18/15/2024	16-11-2024	16-12-2024	Base 2	1.2.4	210 kg/cm2	226.67	225.19	do
	F.18/16/2024						217.78		
3.1	F.18/17/2024						231.11		
	F.18/18/2024	18-11-2024	16-12-2024	Retaining wall 1	1.2.4	210 kg/cm2	226.67	228.15	do
	F.18/19/2024						226.67		
3.2	F.18/20/2024						235.56		
	F.18/21/2024	18-11-2024	16-12-2024	Retaining wall 1	1.2.4	210 kg/cm2	222.22	226.67	do
	F.18/22/2024						222.22		
4.1	F.18/23/2024						231.11		
	F.18/24/2024	19-11-2024	17-12-2024	Base 3	1.2.4	210 kg/cm2	222.22	225.18	do
	F.18/25/2024						222.22		
4.2	F.18/26/2024						231.11		
	F.18/27/2024	19-11-2024	17-12-2024	Base 3	1.2.4	210 kg/cm2	222.22	225.18	do
	F.18/28/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of existing protection wall along the field side at Agalli in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.18/29/2024						235.56		No. 356/ SD III/ WD III/ WRD/24-25/ 304 DATED: 29-11-2024
	F.18/30/2024	20-11-2024	18-12-2024	Retaining wall 2	1.2.4	210 kg/cm2	222.22	225.19	
	F.18/31/2024						217.78		
5.2	F.18/32/2024						231.11		
	F.18/33/2024	20-11-2024	18-12-2024	Retaining wall 2	1.2.4	210 kg/cm2	222.22	222.22	do
	F.18/34/2024						213.33		
6.1	F.18/35/2024						231.11		
	F.18/36/2024	22-11-2024	20-12-2024	Retaining wall 3	1.2.4	210 kg/cm2	222.22	223.70	do
	F.18/37/2024						217.78		
6.2	F.18/38/2024						231.11		
	F.18/39/2024	22-11-2024	20-12-2024	Retaining wall 3	1.2.4	210 kg/cm2	231.11	228.15	do
	F.18/40/2024						222.22		
7.1	F.18/41/2024						235.56		
	F.18/42/2024	25-11-2024	23-12-2024	Base 4 Retaining wall 4	1.2.4	210 kg/cm2	231.11	229.63	do
	F.18/43/2024						222.22		
7.2	F.18/44/2024						235.56		
	F.18/45/2024	25-11-2024	23-12-2024	Base 4 Retaining wall 4	1.2.4	210 kg/cm2	222.22	228.15	do
	F.18/46/2024						226.67		
8.1	F.18/47/2024						231.11		
	F.18/49/2024	27-11-2024	26-12-2024	Retaining wall 5	1.2.4	210 kg/cm2	226.67	225.19	do
	F.18/50/2024						217.78		
8.2	F.18/51/2024						235.56		
	F.18/52/2024	27-11-2024	26-12-2024	Retaining wall 5	1.2.4	210 kg/cm2	231.11	228.15	do
	F.18/53/2024						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of existing protection wall along the field side at Agalli in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.18/54/2024						231.11		No. 356/ SD III/ WD III/
	F.18/55/2024	29-11-2024	27-12-2024	Retaining wall 6	1.2.4	210 kg/cm2	231.11	226.67	WRD/24-25/304
	F.18/56/2024						217.78		DATED: 29-11-2024
9.2	F.18/57/2024						235.56		
	F.18/58/2024	29-11-2024	27-12-2024	Retaining wall 6	1.2.4	210 kg/cm2	231.11	228.15	do
	F.18/59/2024						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER