

NO.WRD/WDXI/SDIII/TECH/W.F.11/2024/2024-25/265

Dated:-02/01/25

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the left bank waterways/ nallah at Avadh Adulshe in V.P.Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.11/11/2024						226.67		No. WRD/WD XI/ SD IV/ W.F 534/ 460 /2024-25. DATED: 05-12-2024.
	F.11/12/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.11/13/2024						226.67		
1.2	F.11/14/2024						235.56		
	F.11/15/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	222.22	231.11	do
	F.11/16/2024						235.56		
1.3	F.11/17/2024						217.78		
	F.11/18/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.11/19/2024						235.56		
1.4	F.11/20/2024						240.00		
	F.11/21/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	226.67	231.11	do
	F.11/22/2024						226.67		
2.1	F.11/23/2024						235.56		
	F.11/24/2024	17-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	222.22	229.63	do
	F.11/25/2024						231.11		
2.2	F.11/26/2024						226.67		
	F.11/27/2024	17-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.11/28/2024						231.11		
2.3	F.11/29/2024						222.22		
	F.11/30/2024	17-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.11/31/2024						231.11		
2.4	F.11/32/2024						235.56		
	F.11/33/2024	17-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	222.22	229.63	do
	F.11/34/2024						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the left bank waterways/ nallah at Avadh Adulshe in V.P.Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.11/35/2024						235.56		No. WRD/WD XI/ SD IV/ W.F 534/ 460 /2024-25. DATED: 05-12-2024.
	F.11/36/2024	18-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	226.67	231.11	
	F.11/37/2024						231.11		
3.2	F.11/38/2024						226.67		
	F.11/39/2024	18-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.11/40/2024						226.67		
3.3	F.11/41/2024						231.11		
	F.11/42/2024	18-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	235.56	226.67	do
	F.11/43/2024						213.33		
3.4	F.11/44/2024						222.22		
	F.11/45/2024	18-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	240.00	229.63	do
	F.11/46/2024						226.67		
4.1	F.11/47/2024						226.67		
	F.11/48/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	240.00	229.63	do
	F.11/49/2024						222.22		
4.2	F.11/50/2024						231.11		
	F.11/51/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	235.56	228.15	do
	F.11/52/2024						217.78		
4.3	F.11/53/2024						235.56		
	F.11/54/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.11/55/2024						222.22		
4.4	F.11/56/2024						231.11		
	F.11/57/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	240.00	231.11	do
	F.11/58/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the left bank waterways/ nallah at Avadh Adulshe in V.P.Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.11/59/2024						231.11		No. WRD/WD XI/ SD IV/ W.F 534/ 460 /2024-25. DATED: 05-12-2024.
	F.11/60/2024	20-11-2024	18-12-2024	For Foundation Base	1.2.4	210 kg/cm2	217.78	231.11	
	F.11/61/2024						244.44		
5.2	F.11/62/2024						231.11		
	F.11/63/2024	20-11-2024	18-12-2024	For Foundation Base	1.2.4	210 kg/cm2	231.11	229.63	do
	F.11/64/2024						226.67		
6.1	F.11/65/2024						235.56		
	F.11/66/2024	21-11-2024	20-12-2024	For Foundation Base	1.2.4	210 kg/cm2	222.22	226.67	do
	F.11/67/2024						222.22		
6.2	F.11/68/2024						231.11		
	F.11/69/2024	21-11-2024	20-12-2024	For Foundation Base	1.2.4	210 kg/cm2	231.11	228.15	do
	F.11/70/2024						222.22		
7.1	F.11/71/2024						235.56		
	F.11/72/2024	28-11-2024	26-12-2024	For Middle band	1.2.4	210 kg/cm2	213.33	226.67	do
	F.11/73/2024						231.11		
7.2	F.11/74/2024						240.00		
	F.11/75/2024	28-11-2024	26-12-2024	For Middle band	1.2.4	210 kg/cm2	217.78	228.15	do
	F.11/76/2024						226.67		
8.1	F.11/77/2024						226.67		
	F.11/78/2024	4/12/2024	1/1/2025	For Top band	1.2.4	210 kg/cm2	226.67	229.63	do
	F.11/79/2024						235.56		
8.2	F.11/80/2024						231.11		
	F.11/81/2024	4/12/2024	1/1/2025	For Top band	1.2.4	210 kg/cm2	222.22	226.67	do
	F.11/82/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER