

NO.WRD/WDXI/SDIII/TECH/W.F. 16-2024/2024-25/ 294 . Dated:-20/1/25

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of protection wall for collapsed banks at Sy.No. 55/1 at Sernabatim Village of Colva Village Panchayat in Benaulim Constituency under Disaster Management.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.16/06/2024						231.11		No. WRD/SD I/ WD II//
	F.16/07/2024	19-12-2024	17-01-2025	Foundation	1.2.4	210 kg/cm2	226.67	228.15	F.Esst/ 393 /2024-25.
	F.16/08/2024						226.67		DATED: 14-01-2025
1.2	F.16/09/2024						231.11		
	F.16/10/2024	19-12-2024	17-01-2025	Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.16/11/2024						231.11		
2.1	F.16/12/2024						217.78		
	F.16/13/2024	20-12-2024	17-01-2025	PCC band 1	1.2.4	210 kg/cm2	231.11	228.15	do
	F.16/14/2024						235.56		
2.2	F.16/15/2024						231.11		
	F.16/16/2024	20-12-2024	17-01-2025	PCC band 1	1.2.4	210 kg/cm2	226.67	228.15	do
	F.16/17/2024						226.67		
3.1	F.16/18/2024						235.56		
	F.16/19/2024	21-12-2024	18-01-2025	PCC band 2	1.2.4	210 kg/cm2	222.22	226.67	do
	F.16/20/2024						222.22		
3.2	F.16/21/2024						231.11		
	F.16/22/2024	21-12-2024	18-01-2025	PCC band 2	1.2.4	210 kg/cm2	213.33	225.18	do
	F.16/23/2024						231.11		
4.1	F.16/24/2024						235.56		
	F.16/25/2024	22-12-2024	19-01-2025	PCC band 3	1.2.4	210 kg/cm2	217.78	229.63	do
	F.16/26/2024						235.56		
4.2	F.16/27/2024						231.11		
	F.16/28/2024	22-12-2024	19-01-2025	PCC band 3	1.2.4	210 kg/cm2	217.78	226.67	do
	F.16/29/2024						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER