

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / TECH / WF.11-2022 / 30 /2022-23.

Dated: **07-11-2022**

Name of the Work: Construction of culvert across D2 Distribution canal of Salaulim Irrigation Project in Sy.No.168/1 in Village Sao Jose De Areal of Salcete Taluka (2nd Call).

Sample Sent by: Assistant Engineer , SD II , WD XII , WRD , Gogol- Margao- Goa.

Letter No: WRD /WD XII/SD II/F. 61/251/2022-23.

Dated:- 1/11/2022

Received on: 1/11/2022

Date of Testing 4/11/2022

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.11/01/2022	Coarse Sand	FM Silt & Clay Grading	2.480 1.60% Zone II	2.3 to 3.1 Upto 5% Zone I to III	
F.11/02/2022	Aggregate-20 mm	Grading		As per IS-383:2016	To get the 20mm graded aggregate nominal size blend
F.11/03/2022	Aggregate- 10 mm	Grading		As per IS-383:2016	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

- Copy submitted to
- 1) Assistant Engineer, SD II, WD XII , WRD Gogol- Margao- Goa.
 - 2) The Executive Engineer, Works Division XII, WRD, Gogol- Margao- Goa.
 - 3) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
 - 4) Office File.