

NO.WRD/WDXI/SDIII/TECH/W.F.14/2024/2024-25/218

Dated:-1/12/24

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank near bandhara at Goval of V.P. Xeldem of Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.14/06/2024						231.11		No. WRD/ SD V/ WD XII/
	F.14/07/2024	1/11/2024	29-11-2024	Foundation	1.2.4	210 kg/cm2	226.67	226.67	F. 70/ 140 /2024-25.
	F.14/08/2024						222.22		DATED: 14-11-2024.
2	F.14/09/2024						235.56		
	F.14/10/2024	2/11/2024	30-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.14/11/2024						217.78		
3	F.14/12/2024						231.11		
	F.14/13/2024	4/11/2024	2/12/2024	Foundation	1.2.4	210 kg/cm2	217.78	225.19	do
	F.14/14/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank near bandhara at Goval of V.P. Xeldem of Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.14/15/2024						240.00		No. WRD/ SD V/ WD XII/
	F.14/16/2024	13-12-2024	10/1/2025	Super Structure	1.2.4	210 kg/cm2	222.22	231.11	F. 70/ 164 /2024-25.
	F.14/17/2024						231.11		DATED: 18-12-2024.
4.2	F.14/18/2024						226.67		
	F.14/19/2024	13-12-2024	10/1/2025	Super Structure	1.2.4	210 kg/cm2	235.56	228.15	do
	F.14/20/2024						222.22		
4.3	F.14/21/2024						226.67		
	F.14/22/2024	13-12-2024	10/1/2025	Super Structure	1.2.4	210 kg/cm2	231.11	229.63	do
	F.14/23/2024						231.11		
5.1	F.14/24/2024						222.22		
	F.14/25/2024	16-12-2024	13-01-2025	Super Structure	1.2.4	210 kg/cm2	231.11	226.67	do
	F.14/26/2024						226.67		
5.2	F.14/27/2024						231.11		
	F.14/28/2024	16-12-2024	13-01-2025	Super Structure	1.2.4	210 kg/cm2	235.56	228.15	do
	F.14/29/2024						217.78		
5.3	F.14/30/2024						226.67		
	F.14/31/2024	16-12-2024	13-01-2025	Super Structure	1.2.4	210 kg/cm2	222.22	229.63	do
	F.14/32/2024						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.14/2024/2024-25/ 308
GOVERNMENT OF GOA

Dated:-27/01/25

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank near bandhara at Goval of V.P. Xeldem of Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.14/33/2024						226.67		No. WRD/ SD V/ WD XII/ F. 70/ 176 /2024-25. DATED: 10-01-2025.
	F.14/34/2024	28-12-2024	25-01-2025	Concrete band	1.2.4	210 kg/cm2	222.22	226.67	
	F.14/35/2024						231.11		
6.2	F.14/36/2024						235.56		
	F.14/37/2024	28-12-2024	25-01-2025	Concrete band	1.2.4	210 kg/cm2	226.67	228.15	do
	F.14/38/2024						222.22		
6.3	F.14/39/2024						231.11		
	F.14/40/2024	28-12-2024	25-01-2025	Concrete band	1.2.4	210 kg/cm2	226.67	228.15	do
	F.14/41/2024						226.67		
7.1	F.14/42/2024						217.78		
	F.14/43/2024	30-12-2024	27-01-2025	Concrete band	1.2.4	210 kg/cm2	235.56	231.11	do
	F.14/44/2024						240.00		
7.2	F.14/45/2024						231.11		
	F.14/46/2024	30-12-2024	27-01-2025	Concrete band	1.2.4	210 kg/cm2	222.22	228.15	do
	F.14/47/2024						231.11		
7.3	F.14/49/2024						231.11		
	F.14/50/2024	30-12-2024	27-01-2025	Concrete band	1.2.4	210 kg/cm2	235.56	231.11	do
	F.14/51/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER