

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of flood protection wall for properties under Sy.No. 55/15 & 16 on Zuari river at Khamamol in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.78/06/2022						235.56		No. WRD/SD V/ WD XII/ F.70/45/2023-24. DATED: 19-05-2023
	F.78/07/2022	26-04-2023	24-05-2023	Foundation Retaining Wall	1.2.4	210 kg/cm2	231.11	229.63	
	F.78/08/2022						222.22		
1.2	F.78/09/2022						226.67		
	F.78/10/2022	26-04-2023	24-05-2023	Foundation Retaining Wall	1.2.4	210 kg/cm2	231.11	231.11	do
	F.78/11/2022						235.56		
2.1	F.78/12/2022						226.67		
	F.78/13/2022	28-04-2023	26-05-2023	1st Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	225.19	do
	F.78/14/2022						222.22		
2.2	F.78/15/2022						231.11		
	F.78/16/2022	28-04-2023	26-05-2023	1st Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	225.19	do
	F.78/17/2022						217.78		
3.1	F.78/18/2022						231.11		
	F.78/19/2022	30-04-2023	28-05-2023	2nd Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	232.59	do
	F.78/20/2022						240.00		
3.2	F.78/21/2022						235.56		
	F.78/22/2022	30-04-2023	28-05-2023	2nd Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	231.11	do
	F.78/23/2022						231.11		
4.1	F.78/24/2022						231.11		
	F.78/25/2022	2/5/2023	30-05-2023	3rd Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.78/26/2022						222.22		
4.2	F.78/27/2022						226.67		
	F.78/28/2022	2/5/2023	30-05-2023	3rd Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	228.15	do
	F.78/29/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of flood protection wall for properties under Sy.No. 55/15 & 16 on Zuari river at Khamamol in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.78/30/2022						235.56		No. WRD/WD XII/SD V/ F.70/45/2023-24. DATED: 19-05-2023
	F.78/31/2022	4/5/2023	1/6/2023	Foundation Retaining Wall	1.2.4	210 kg/cm2	235.56	234.08	
	F.78/32/2022						231.11		
5.2	F.78/33/2022						240.00		
	F.78/34/2022	4/5/2023	1/6/2023	Foundation Retaining Wall	1.2.4	210 kg/cm2	231.11	234.07	do
	F.78/35/2022						231.11		
6.1	F.78/36/2022						222.22		
	F.78/37/2022	6/5/2023	3/6/2023	1st Lift Retaining Wall	1.2.4	210 kg/cm2	235.56	228.15	do
	F.78/38/2022						226.67		
6.2	F.78/39/2022						231.11		
	F.78/40/2022	6/5/2023	3/6/2023	1st Lift Retaining Wall	1.2.4	210 kg/cm2	217.78	226.67	do
	F.78/41/2022						231.11		
7.1	F.78/42/2022						244.44		
	F.78/43/2022	8/5/2023	5/6/2023	2nd Lift Retaining Wall	1.2.4	210 kg/cm2	231.11	235.55	do
	F.78/44/2022						231.11		
7.2	F.78/45/2022						235.56		
	F.78/46/2022	8/5/2023	5/6/2023	2nd Lift Retaining Wall	1.2.4	210 kg/cm2	235.56	234.08	do
	F.78/47/2022						231.11		
8.1	F.78/48/2022						231.11		
	F.78/49/2022	10/5/2023	7/6/2023	3rd Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	228.15	do
	F.78/50/2022						226.67		
8.2	F.78/51/2022						222.22		
	F.78/52/2022	10/5/2023	7/6/2023	3rd Lift Retaining Wall	1.2.4	210 kg/cm2	231.11	229.63	do
	F.78/53/2022						235.56		

JUNIOR ENGINEER.

NO: WRD /WD XI / SD III/ TECH/W.F. 78-2022/147 / 2023-24

ASSISTANT ENGINEER

Dated:20/06/2023

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of flood protection wall for properties under Sy.No. 55/15 & 16 on Zuari river at Khamamol in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.78/54/2022						231.11		No. WRD/SD V/WD XII/ F.70/ 60 /2023-24. DATED: 08-06-2023
	F.78/55/2022	15-05-2023	12/6/2023	4th Lift Retaining Wall	1.2.4	210 kg/cm2	231.11	232.59	
	F.78/56/2022						235.56		
9.2	F.78/57/2022						235.56		
	F.78/58/2022	15-05-2023	12/6/2023	4th Lift Retaining Wall	1.2.4	210 kg/cm2	235.56	234.08	do
	F.78/59/2022						231.11		
10.1	F.78/60/2022						240.00		
	F.78/61/2022	17-05-2023	14-06-2023	5th Lift Retaining wall	1.2.4	210 kg/cm2	231.11	228.15	do
	F.78/62/2022						213.33		
10.2	F.78/63/2022						231.11		
	F.78/64/2022	17-05-2023	14-06-2023	5th Lift Retaining wall	1.2.4	210 kg/cm2	235.56	231.11	do
	F.78/65/2022						226.67		
11.1	F.78/66/2022						226.67		
	F.78/67/2022	19-05-2023	16-06-2023	4th Lift Retaining Wall	1.2.4	210 kg/cm2	226.67	225.19	do
	F.78/68/2022						222.22		
11.2	F.78/69/2022						226.67		
	F.78/70/2022	19-05-2023	16-06-2023	4th Lift Retaining Wall	1.2.4	210 kg/cm2	231.11	228.15	do
	F.78/71/2022						226.67		
12.1	F.78/72/2022						244.44		
	F.78/73/2022	21-05-2023	19-06-2023	5th Lift Retaining wall	1.2.4	210 kg/cm2	231.11	238.52	do
	F.78/74/2022						240.00		

Carrie Correia
JUNIOR ENGINEER.

S.S. Velingkar
ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of flood protection wall for properties under Sy.No. 55/15 & 16 on Zuari river at Khamamol in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
12.2	F.78/75/2022						231.11		No. WRD/WD XII/SD V/
	F.78/76/2022	21-05-2023	19-06-2023	5th Lift Retaining wall	1.2.4	210 kg/cm2	240.00	234.07	F.70/60/2023-24.
	F.78/77/2022						231.11		DATED: 08-06-2023
13.1	F.78/78/2022						235.56		
	F.78/79/2022	23-05-2023	20-06-2023	6th Lift Retaining wall	1.2.4	210 kg/cm2	222.22	228.15	do
	F.78/80/2022						226.67		
13.2	F.78/81/2022						222.22		
	F.78/82/2022	23-05-2023	20-06-2023	6th Lift Retaining wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.78/83/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER