

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal (at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	4043						177.78		No. WRD/ SD I/WD XII/ F.47/468/2020-21. DATED: 12-03-2021
	4044	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	177.78	176.30	
	4045			for Retaining wall RHS of Tank (Tali)			173.33		
1.2	4046						177.78		
	4047	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	168.89	173.33	do
	4048			for Retaining wall RHS of Tank (Tali)			173.33		
1.3	4049						168.89		
	4050	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	173.33	171.85	do
	4051			for Retaining wall RHS of Tank (Tali)			173.33		
1.4	4052						173.33		
	4053	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	do
	4054			for Retaining wall RHS of Tank (Tali)			173.33		
1.5	4055						173.33		
	4056	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	168.89	171.85	do
	4057			for Retaining wall RHS of Tank (Tali)			173.33		
1.6	4058						173.33		
	4059	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	do
	4060			for Retaining wall RHS of Tank (Tali)			173.33		
1.7	4061						173.33		
	4062	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	177.78	176.30	do
	4063			for Retaining wall RHS of Tank (Tali)			177.78		
1.8	4064						173.33		
	4065	24-02-2021	24-03-2021	Ch. 0.00 mt to 15.00 mts Foundation	1.2.4	150 kg/cm2	168.89	171.85	do
	4066			for Retaining wall RHS of Tank (Tali)			173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal (at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.1	4067						173.33		No. WRD/ SD I/WD XII/ F.47/468/2020-21. DATED: 12-03-2021
	4068	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	4069			for Retaining wall RHS of Tank (Tali)			173.33		
2.2	4070						177.78		do
	4071	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	177.78	177.78	
	4072			for Retaining wall RHS of Tank (Tali)			177.78		
2.3	4073						177.78		do
	4074	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	173.33	176.30	
	4075			for Retaining wall RHS of Tank (Tali)			177.78		
2.4	4076						173.33		do
	4077	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	168.89	171.85	
	4078			for Retaining wall RHS of Tank (Tali)			173.33		
2.5	4079						168.89		do
	4080	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	173.33	171.85	
	4081			for Retaining wall RHS of Tank (Tali)			173.33		
2.6	4082						168.89		do
	4083	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	4084			for Retaining wall RHS of Tank (Tali)			168.89		
2.7	4085						177.78		do
	4086	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	173.33	174.81	
	4087			for Retaining wall RHS of Tank (Tali)			173.33		
2.8	4088						177.78		do
	4089	25-02-2021	25-03-2021	Ch. 15.00 mt to 29.00 mts Foundation	1.2.4	150 kg/cm2	173.33	176.30	
	4090			for Retaining wall RHS of Tank (Tali)			177.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal (at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	4091						177.78		No. WRD/ SD I/WD XII/ F.47/468/2020-21. DATED: 12-03-2021
	4092	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	177.78	176.30	
	4093			for Retaining wall RHS of Tank (Tali)			173.33		
3.2	4094						177.78		do
	4095	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	168.89	173.33	
	4096			for Retaining wall RHS of Tank (Tali)			173.33		
3.3	4097						168.89		do
	4098	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	173.33	171.85	
	4099			for Retaining wall RHS of Tank (Tali)			173.33		
3.4	4100						173.33		do
	4101	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	4102			for Retaining wall RHS of Tank (Tali)			173.33		
3.5	4103						173.33		do
	4104	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	168.89	171.85	
	4105			for Retaining wall RHS of Tank (Tali)			173.33		
3.6	4106						173.33		do
	4107	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	4108			for Retaining wall RHS of Tank (Tali)			173.33		
3.7	4109						173.33		do
	4110	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	177.78	176.30	
	4111			for Retaining wall RHS of Tank (Tali)			177.78		
3.8	4112						173.33		do
	4113	26-02-2021	26-03-2021	Ch. 29.00 mt to 44.00 mts Foundation	1.2.4	150 kg/cm2	168.89	171.85	
	4114			for Retaining wall RHS of Tank (Tali)			173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal (at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	4115						248.89		No. WRD/ SD I/WD XII/ F.47/468/2020-21. DATED: 12-03-2021
	4116	26-02-2021	26-03-2021	Ch. 0.00 mts to 10.00 mts Foundation	1.1.5.3	200 kg/cm2	253.33	250.37	
	4117			for RCC Spring wall			248.89		
4.2	4118						248.89		
	4119	26-02-2021	26-03-2021	Ch. 0.00 mts to 10.00 mts Foundation	1.1.5.3	200 kg/cm2	253.33	251.85	do
	4120			for RCC Spring wall			253.33		
5.1	4121						177.78		
	4122	27-02-2021	27-03-2021	Ch. 44.00 mt to 51.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	do
	4123			for Retaining wall RHS of Tank (Tali)			168.89		
5.2	4124						173.33		
	4125	27-02-2021	27-03-2021	Ch. 44.00 mt to 51.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	do
	4126			for Retaining wall RHS of Tank (Tali)			173.33		
5.3	4127						177.78		
	4128	27-02-2021	27-03-2021	Ch. 44.00 mt to 51.00 mts Foundation	1.2.4	150 kg/cm2	177.78	174.82	do
	4129			for Retaining wall RHS of Tank (Tali)			168.89		
5.4	4130						173.33		
	4131	27-02-2021	27-03-2021	Ch. 44.00 mt to 51.00 mts Foundation	1.2.4	150 kg/cm2	173.33	173.33	do
	4132			for Retaining wall RHS of Tank (Tali)			173.33		
6.1	4133			Ch. 10.00 mts to 16.00 mts foundation			253.33		
	4134	27-02-2021	27-03-2021	for RCC Spring Wall & 1st Lift Ch. 0.00	1.1.5.3	200 kg/cm2	257.78	254.81	do
	4135			mt to 10.00 mts.			253.33		
6.2	4136			Ch. 10.00 mts to 16.00 mts foundation			253.33		
	4137	27-02-2021	27-03-2021	for RCC Spring Wall & 1st Lift Ch. 0.00	1.1.5.3	200 kg/cm2	253.33	253.33	do
	4138			mt to 10.00 mts.			253.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal (at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.3	4139			Ch. 10.00 mts to 16.00 mts foundation for RCC Spring Wall & 1st Lift Ch. 0.00 mt to 10.00 mts.			257.78		No. WRD/ SD I/WD XII/ F.47/468/2020-21. DATED: 12-03-2021
	4140	27-02-2021	27-03-2021		1.1.5.3	200 kg/cm2	262.22	259.26	
	4141						257.78		
6.4	4142			Ch. 10.00 mts to 16.00 mts foundation for RCC Spring Wall & 1st Lift Ch. 0.00 mt to 10.00 mts.			257.78		do
	4143	27-02-2021	27-03-2021		1.1.5.3	200 kg/cm2	257.78	259.26	
	4144						262.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER