

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of drain to the tributary of Aquem Baixo nallah at Aquem Baixo , Margao- Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.87/06/2021						164.44		No. 293/SD III/ WD III/
	F.87/07/2021	4/2/2022	4/3/2022	RHS wall foundation Ch.0 to 160.00 mts	1.2.4	150 kg/cm2	164.44	164.44	WRD/2021-22/488.
	F.87/08/2021						164.44		DATED:- 11-02-2022
2.1	F.87/09/2021						240.00		
	F.87/10/2021	7/2/2022	7/3/2022	RHS RCC bed Ch.0 to 160.00 mts	1.1.5.3	200 kg/cm2	231.11	235.56	do
	F.87/11/2021						235.56		
2.2	F.87/12/2021						240.00		
	F.87/13/2021	7/2/2022	7/3/2022	RHS RCC bed Ch.0 to 160.00 mts	1.1.5.3	200 kg/cm2	235.56	237.04	do
	F.87/14/2021						235.56		
3.1	F.87/15/2021						231.11		
	F.87/16/2021	11/2/2022	11/3/2022	RHS RCC Retaining wall Ch. 0 to 160.00 mts	1.1.5.3	200 kg/cm2	231.11	231.11	do
	F.87/17/2021						231.11		
3.2	F.87/18/2021						240.00		
	F.87/19/2021	11/2/2022	11/3/2022	RHS RCC Retaining wall Ch. 0 to 160.00 mts	1.1.5.3	200 kg/cm2	231.11	235.56	do
	F.87/20/2021						235.56		
3.3	F.87/21/2021						244.44		
	F.87/22/2021	11/2/2022	11/3/2022	RHS RCC Retaining wall Ch. 0 to 160.00 mts	1.1.5.3	200 kg/cm2	240.00	238.52	do
	F.87/23/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER