

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near Kalpataru Society Aquem- Baixo, Margao Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.89/05/2021						168.89		No.294/SD III/WDIII/
	F.89/06/2021	24-01-2022	21-02-2022	wall foundation RHS Ch. 0 to 14.00 mts	1.2.4	150 kg/cm2	168.89	168.89	WRD/2021-22/470.
	F.89/07/2021						168.89		DATED: 29-01-2022.
2.1	F.89/08/2021						164.44		
	F.89/09/2021	25-01-2022	22-02-2022	wall foundation LHS Ch. 0 to 21.00 mts	1.2.4	150 kg/cm2	164.44	165.92	do
	F.89/10/2021						168.89		
2.2	F.89/11/2021						164.44		
	F.89/12/2021	25-01-2022	22-02-2022	wall foundation LHS Ch. 0 to 21.00 mts	1.2.4	150 kg/cm2	168.89	167.41	do
	F.89/13/2021						168.89		
3	F.89/14/2021						164.44		
	F.89/15/2021	27-01-2022	24-02-2022	RHS 1st Lift Ch. 0 to 14.00 mts	1.2.4	150 kg/cm2	168.89	167.41	do
	F.89/16/2021						168.89		
4.1	F.89/17/2021						164.44		
	F.89/18/2021	28-01-2022	25-02-2022	LHS 1 st Lift Ch. 0 to 21.00 mts	1.2.4	150 kg/cm2	164.44	164.44	do
	F.89/19/2021						164.44		
4.2	F.89/20/2021						164.44		
	F.89/21/2021	28-01-2022	25-02-2022	LHS 1 st Lift Ch. 0 to 21.00 mts	1.2.4	150 kg/cm2	164.44	165.92	do
	F.89/22/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near Kalpataru Society Aquem- Baixo, Margao Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.89/23/2021						168.89		No.294/SD III/WDIII/
	F.89/24/2021	4/2/2022	4/3/2022	LHS 2nd lift retaining wall Ch. 0 to 14.00 mts	1.2.4	150 kg/cm2	168.89	167.41	WRD/2021-22/487.
	F.89/25/2021						164.44		DATED: 10-02-2022.
2	F.89/26/2021						164.44		
	F.89/27/2021	7/2/2022	7/3/2022	Wall foundation RHS 2nd lift retaining wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.89/28/2021			Ch. 0 to 21.00 mts			168.89		
3	F.89/29/2021						164.44		
	F.89/30/2021	9/2/2022	9/3/2022	LHS above existing retaining wall Ch.	1.2.4	150 kg/cm2	164.44	164.44	do
	F.89/31/2021			14 to 47.50 mts			164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER