

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall in Sy.No. 282/2 in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.120/01/2021						155.56		No. WRD/ SD I/ WD II/
	F.120/02/2021	16-02-2022	16-03-2022	Foundation	1.2.4	150 kg/cm2	155.56	154.08	F.Estt/791/2021-22.
	F.120/03/2021						151.11		DATED: 07-03-2022
1.2	F.120/04/2021						160.00		
	F.120/05/2021	16-02-2022	16-03-2022	Foundation	1.2.4	150 kg/cm2	155.56	157.04	do
	F.120/06/2021						155.56		
2.1	F.120/07/2021						160.00		
	F.120/08/2021	18-02-2022	18-03-2022	Foundation	1.2.4	150 kg/cm2	160.00	160.00	do
	F.120/09/2021						160.00		
2.2	F.120/10/2021						155.56		
	F.120/11/2021	18-02-2022	18-03-2022	Foundation	1.2.4	150 kg/cm2	164.44	161.48	do
	F.120/12/2021						164.44		
3.1	F.120/13/2021						160.00		
	F.120/14/2021	22-02-2022	22-03-2022	Foundation	1.2.4	150 kg/cm2	160.00	158.52	do
	F.120/15/2021						155.56		
3.2	F.120/16/2021						168.89		
	F.120/17/2021	22-02-2022	22-03-2022	Foundation	1.2.4	150 kg/cm2	155.56	158.52	do
	F.120/18/2021						151.11		
4.1	F.120/19/2021						160.00		
	F.120/20/2021	24-02-2022	24-03-2022	Wall	1.2.4	150 kg/cm2	160.00	161.48	do
	F.120/21/2021						164.44		
4.2	F.120/22/2021						168.89		
	F.120/23/2021	24-02-2022	24-03-2022	Wall	1.2.4	150 kg/cm2	155.56	158.52	do
	F.120/24/2021						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall in Sy.No. 282/2 in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.120/25/2021						155.56		No. WRD/ SD I/ WD II/
	F.120/26/2021	26-02-2022	26-03-2022	Wall	1.2.4	150 kg/cm2	151.11	155.56	F.Estt/791/2021-22.
	F.120/27/2021						160.00		DATED: 07-03-2022
5.2	F.120/28/2021						155.56		
	F.120/29/2021	26-02-2022	26-03-2022	Wall	1.2.4	150 kg/cm2	151.11	154.08	do
	F.120/30/2021						155.56		
6.1	F.120/31/2021						155.56		
	F.120/32/2021	1/3/2022	29-03-2022	Wall	1.2.4	150 kg/cm2	160.00	157.04	do
	F.120/33/2021						155.56		
6.2	F.120/34/2021						155.56		
	F.120/35/2021	1/3/2022	29-03-2022	Wall	1.2.4	150 kg/cm2	151.11	152.59	do
	F.120/36/2021						151.11		
7.1	F.120/37/2021						155.56		
	F.120/38/2021	3/3/2022	31-03-2022	Wall	1.2.4	150 kg/cm2	160.00	155.56	do
	F.120/39/2021						151.11		
7.2	F.120/40/2021						155.56		
	F.120/41/2021	3/3/2022	31-03-2022	Wall	1.2.4	150 kg/cm2	160.00	155.56	do
	F.120/42/2021						151.11		
8.1	F.120/43/2021						155.56		
	F.120/44/2021	4/3/2022	1/4/2022	Wall	1.2.4	150 kg/cm2	160.00	158.52	do
	F.120/45/2021						160.00		
8.2	F.120/46/2021						155.56		
	F.120/47/2021	4/3/2022	1/4/2022	Wall	1.2.4	150 kg/cm2	160.00	155.56	do
	F.120/48/2021						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER