

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to Boxechem tollem at Bamboll Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.132/01/2021						222.22		No. WRD/SD I/WD II/ F.Estt/790/2021-22. DATED: 07-03-2022.
	F.132/02/2021	21-02-2022	21-03-2022	Foundation	1.2.4	210 kg/cm2	231.11	225.18	
	F.132/03/2021						222.22		
1.2	F.132/04/2021						217.78		
	F.132/05/2021	21-02-2022	21-03-2022	Foundation	1.2.4	210 kg/cm2	222.22	220.74	do
	F.132/06/2021						222.22		
2.1	F.132/07/2021						231.11		
	F.132/08/2021	22-02-2022	22-03-2022	Foundation	1.2.4	210 kg/cm2	222.22	223.70	do
	F.132/09/2021						217.78		
2.2	F.132/10/2021						231.11		
	F.132/11/2021	22-02-2022	22-03-2022	Foundation	1.2.4	210 kg/cm2	217.78	226.67	do
	F.132/12/2021						231.11		
3.1	F.132/13/2021						231.11		
	F.132/14/2021	23-02-2022	23-03-2022	Foundation & Wall	1.2.4	210 kg/cm2	231.11	228.15	do
	F.132/15/2021						222.22		
3.2	F.132/16/2021						217.78		
	F.132/17/2021	23-02-2022	23-03-2022	Foundation & Wall	1.2.4	210 kg/cm2	226.67	222.22	do
	F.132/18/2021						222.22		
4.1	F.132/19/2021						217.78		
	F.132/20/2021	24-02-2022	24-03-2022	Wall	1.2.4	210 kg/cm2	235.56	228.15	do
	F.132/21/2021						231.11		
4.2	F.132/22/2021						222.22		
	F.132/23/2021	24-02-2022	24-03-2022	Wall	1.2.4	210 kg/cm2	217.78	223.70	do
	F.132/24/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to Boxechem tollem at Bamboll Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.132/25/2021						231.11		No. WRD/SD I/WD II/ F.Estt/790/2021-22. DATED: 07-03-2022.
	F.132/26/2021	25-02-2022	25-03-2022	Wall	1.2.4	210 kg/cm2	222.22	223.70	
	F.132/27/2021						217.78		
5.2	F.132/28/2021						231.11		
	F.132/29/2021	25-02-2022	25-03-2022	Wall	1.2.4	210 kg/cm2	217.78	226.67	do
	F.132/30/2021						231.11		
6.1	F.132/31/2021						231.11		
	F.132/32/2021	26-02-2022	26-03-2022	Wall	1.2.4	210 kg/cm2	231.11	228.15	do
	F.132/33/2021						222.22		
6.2	F.132/34/2021						217.78		
	F.132/35/2021	26-02-2022	26-03-2022	Wall	1.2.4	210 kg/cm2	226.67	222.22	do
	F.132/36/2021						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to Boxechem tollem at Bamboll Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.132/37/2021						217.78		No. WRD/SD I/WD II/ F.Estt/76(A)/2021-22. DATED: 26-04-2022.
	F.132/38/2021	19-04-2022	17-05-2022	Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.132/39/2021						222.22		
1.2	F.132/40/2021						231.11		
	F.132/41/2021	19-04-2022	17-05-2022	Foundation	1.2.4	210 kg/cm2	222.22	223.70	do
	F.132/42/2021						217.78		
2.1	F.132/43/2021						231.11		
	F.132/44/2021	20-02-2022	18-05-2022	Foundation	1.2.4	210 kg/cm2	217.78	226.67	do
	F.132/45/2021						231.11		
2.2	F.132/46/2021						222.22		
	F.132/47/2021	20-02-2022	18-05-2022	Foundation	1.2.4	210 kg/cm2	231.11	223.70	do
	F.132/48/2021						217.78		
3.1	F.132/49/2021						217.78		
	F.132/50/2021	21-04-2022	19-05-2022	Foundation	1.2.4	210 kg/cm2	222.22	220.74	do
	F.132/51/2021						222.22		
3.2	F.132/52/2021						226.67		
	F.132/53/2021	21-04-2022	19-05-2022	Foundation	1.2.4	210 kg/cm2	217.78	222.22	do
	F.132/54/2021						222.22		
4.1	F.132/55/2021						217.78		
	F.132/56/2021	22-04-2022	20-05-2022	Wall	1.2.4	210 kg/cm2	222.22	220.74	do
	F.132/57/2021						222.22		
4.2	F.132/58/2021						222.22		
	F.132/59/2021	22-04-2022	20-05-2022	Wall	1.2.4	210 kg/cm2	231.11	223.70	do
	F.132/60/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to Boxechem tollem at Bamboll Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.132/61/2021						213.33		No. WRD/SD I/WD II/
	F.132/62/2021	23-04-2022	21-05-2022	Wall	1.2.4	210 kg/cm2	217.78	220.74	F.Estt/76(A)/2021-22.
	F.132/63/2021						231.11		DATED: 26-04-2022.
5.2	F.132/64/2021						222.22		
	F.132/65/2021	23-04-2022	21-05-2022	Wall	1.2.4	210 kg/cm2	213.33	228.14	do
	F.132/66/2021						248.88		
6.1	F.132/67/2021						226.67		
	F.132/68/2021	25-04-2022	23-05-2022	Wall	1.2.4	210 kg/cm2	217.78	222.22	do
	F.132/69/2021						222.22		
6.2	F.132/70/2021						217.78		
	F.132/71/2021	25-04-2022	23-05-2022	Wall	1.2.4	210 kg/cm2	222.22	220.74	do
	F.132/72/2021						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER