

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall in Sy.No.149/1 from Ch.0.00 m to 95.00m in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.133/06/2021						168.89		No.WRD/SD I/ WD II/
	F.133/07/2021	7/2/2022	7/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	F.Estt/1066/2021-22
	F.133/08/2021						168.89		DATED:- 23-02-2022
1.2	F.133/09/2021						168.89		
	F.133/10/2021	7/2/2022	7/3/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.133/11/2021						168.89		
2.1	F.133/12/2021						173.33		
	F.133/13/2021	9/2/2022	9/3/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.133/14/2021						164.44		
2.2	F.133/15/2021						173.33		
	F.133/16/2021	9/2/2022	9/3/2022	Foundation	1.2.4	150 kg/cm2	168.89	170.37	do
	F.133/17/2021						168.89		
3.1	F.133/18/2021						160.00		
	F.133/19/2021	11/2/2022	11/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	162.96	do
	F.133/20/2021						164.44		
3.2	F.133/21/2021						164.44		
	F.133/22/2021	11/2/2022	11/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	do
	F.133/23/2021						164.44		
4.1	F.133/24/2021						164.44		
	F.133/25/2021	15-02-2022	15-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.133/26/2021						168.89		
4.2	F.133/27/2021						164.44		
	F.133/28/2021	15-02-2022	15-03-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	F.133/29/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall in Sy.No.149/1 from Ch.0.00 m to 95.00m in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanffond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.133/30/2021						168.89		No.WRD/SD I/ WD II/
	F.133/31/2021	17-02-2022	17-03-2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	F.Estt/1066/2021-22
	F.133/32/2021						168.89		DATED:- 23-02-2022
5.2	F.133/33/2021						164.44		
	F.133/34/2021	17-02-2022	17-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.133/35/2021						168.89		
6.1	F.133/36/2021						164.44		
	F.133/37/2021	19-02-2022	19-03-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.133/38/2021						168.89		
6.2	F.133/39/2021						168.89		
	F.133/40/2021	19-02-2022	19-03-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	do
	F.133/41/2021						168.89		
7.1	F.133/42/2021						168.89		
	F.133/43/2021	21-02-2022	21-03-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	do
	F.133/44/2021						168.89		
7.2	F.133/45/2021						168.89		
	F.133/46/2021	21-02-2022	21-03-2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	do
	F.133/47/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER