

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of coastal circuit II under Swadesh Darshan Scheme Reg. Construction of mini convention centre and Development of Rua De Ourem creek side at Patto Panaji, Tiswadi Taluka.

SAMPLE SENT BY: AE , II, Project Cell, GTDC, Patto, Panaji- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	31						373.33		NO:-W.249/PC/GTDC/
	32	26-11-2020	24-12-2020	UGT03	M 35	356.90 Kg/cm2	368.89	370.37	2020-21/AE II/516
	33						368.89		DATED: 23-12-2020
2	34						368.89		
	35	26-11-2020	24-12-2020	RW 20	M 35	356.90 Kg/cm2	373.33	371.85	do
	36						373.33		
3	37						368.89		
	38	26-11-2020	24-12-2020	CO5 (B)	M 35	356.90 Kg/cm2	373.33	371.85	do
	39						373.33		
4	40						373.33		
	41	26-11-2020	24-12-2020	C 31 (a)	M 35	356.90 Kg/cm2	368.89	370.37	do
	42						368.89		

Carrie A. Correia
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER

