

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of coastal circuit II under Swadesh Darshan Scheme Reg. Construction of mini convention centre and Development of Rua De Ourem creek side at Patto Panaji, Tiswadi Taluka.

SAMPLE SENT BY: AE , II, Project Cell, GTDC, Patto, Panaji- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	01						373.33		NO:-W.249/PC/GTDC/
	02	3/11/2020	1/12/2020	C49 (B)	M35	356.90 Kg/cm2	368.89	370.37	2020-21/AE II/464
	03						368.89		DATED: 30-11-2020
2	16						368.89		NO:-W.249/PC/GTDC/
	17	4/11/2020	2/12/2020	C 48 (A)	M35	356.90 Kg/cm2	373.33	371.85	2020-21/AE II/467
	18						373.33		DATED: 02-12-2020

Carrie A. Correia
 JUNIOR ENGINEER.

Pravin C Parsekar
 ASSISTANT ENGINEER