

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / F.59. W.F. 15/2020 / **183** / 2020-21

dated: 11-12-2020

Name of the Work: Construction of retaining wall for the nallah in Sy. No. 60/4, 60/1 & 55/4 at Poriebhat Verna in ward No. 2 in Nuvem Constituency of Salcete Taluka.

Sample Sent by :- Assistant Engineer, SD I, WD II, WRD, Rawanfond- Goa.

letter no:- WRD/ SD I/ WD II/ F.Esst/675/2020-21.

Date:- 27-11-2020

Received on: 8/12/2020

Date of Testing: 11/12/2020

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
64/20	Coarse Sand	FM Silt & Clay Grading	2.552 2.30% Zone II	2.3 to 3.1 Upto 5% I to III Zone	
65/20	Aggregate-20 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	To get the 20mm graded aggregate of nominal size blend 20 mm & 10 mm metal in 1:1:1 proportion.
66/20	Aggregate- 10 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD I, WD II, WRD, Rawanfond-Goa.
- 2) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
- 3) The Executive Engineer, WD II, WRD, Rawanfond-Goa.
- 4) Office File.