

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / F.59 /WF.87/2021/ 46 / 2021-22.

dated: 14/06/21

Name of the Work: Construction of Maidatale lake at Nagarcem in Canacona Taluka.

Sample Sent by: Assistant Engineer, SD II , WD XI, WRD, Canacona-Goa

Letter No: WRD / SD II / WD XI / F.67 / 66 / 2021-22.

Dated:- 11/6/2021

Received on: 11/6/2021

Date of Testing: 14-06-2021

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
468/2021	Coarse Sand	FM Silt & Clay Grading	2.926 3.20% II	2.3 to 3.1 Upto 5% I to III Zone	

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD II, WD XI, WRD, Canacona-Goa.
- 2) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
- 3) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
- 4) Office File.