

**GOVERNMENT OF GOA**  
**WATER RESOURCES DEPARTMENT**  
**S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY**  
**Gogol - Margao - Goa.**

No. WRD / WD XI / SDIII / F.59/W.F. 57/2021 / 197 / 2021-22 . dated: 03/01/2022

Name of the Work: Construction of protection wall for the infront of the capela Mae Devote connecting to the main nallah near the residence of Especiosa Fernandes, Bernadette Fernandes, Joyce Fernandes and Bernardo Reis at Devote in V.P. Loutolim in Nuvem Constituency.

Sample Sent by: Assistant Engineer , SD I , WD II , WRD , Rawanfond- Goa.

Letter No: WRD / SD I/ WD II/ F.Estt/643/2021-22.

Dated:- 29-12-2021

Received on: 29-12-2021

Date of Testing: 31-12-2021

**REPORT**

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.57/01/2021	Coarse Sand	FM Silt & Clay Grading	2.638 2.00% Zone II	2.3 to 3.1 Upto 5% I to III Zone	
F.57/02/2021	Aggregate-20 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	To get the 20mm graded aggregate nominal size blend
F.57/03/2021	Aggregate- 10 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD I, WD II , WRD Rawanfond- Goa.
- 2) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
- 3) Executive Engineer, WD II, WRD, Rawanfond-Goa.
- 4) Office File.