

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / F.59 / WF.108/2021 / 561 / 2021-22.

dated: 18/03/2022

Name of the Work: Construction of protection wall to nallah Shri. Ashok Bhivset bar to Khindir Manus at Varchawada in Village Morjim, Pernem Goa.

Sample Sent by: Assistant Engineer, SD III, WD I, WRD, Pernem -Goa

Letter No: No. MI/SD III/ WD I/ WRD/F.58/2021-22/421.

Dated:- 15-03-2022

Received on: 16-03-2022

Date of Testing 18-03-2022

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.108/1/2021	Coarse Sand	FM Silt & Clay Grading	2.568 3.00% Zone- II	2.3 to 3.1 Upto 5% I to III Zone	
F.108/2/2021	Aggregate-20 mm	Grading		As per IS-383:2016	To get the 20mm graded aggregate nominal size blend 20mm & 12.5 mm metal in 1:1 proportion.
F.108/3/2021	Aggregate- 12.5 mm	Grading		As per IS-383:2016	

Junior Engineer

Assistant Engineer

- Copy submitted to
- 1) Assistant Engineer, SD III, WD I, WRD, Pernem-Goa.
 - 2) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
 - 3) Executive Engineer, WD I, WRD, Porvorim-Goa.
 - 4) Office File.