GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DFEPARTMENT

<u>Test Report No.: WRD/Q.C./F.6-4/ Laterite -T- 0441 /Lab/ 204 /2020-21</u>

<u>Dated: 20/ 01 / 2021. Laboratory: Bicholim</u>

Sub Div: V (QC)/WRD/Bicholim Goa.

<u>Sub</u>: Improvement to waterways at Vadanchi Dhat Shivolkarwada mulgao in Bicholim Goa.

Ref to requisition No: F.36/SDIII/WDVI/WRD/2020-21/165 Dated: 13/01/2021.

Qty. Received: 3 Nos **Date of Receipt**: 14/01/2021 **Tested on**: 15/01/2021 **Ref to Specification:** CPWD 2009, GSR 1980.

Sample: Laterite Stone O.S. No. 4708 Lab. Sample No.: 97 Tested by: Mrs. S. B. Naik Shirodkar.JE.

REPORT 01 OF 01

1. Laterite stone A) Compressive strength test: - i) 44.44 Kg/cm² 35.00kg/cm²

ii) 37.50 Kg /cm²

 $\frac{\text{iii}}{40.86} \frac{40.86 \text{ Kg}}{\text{cm}^2}$

Avg. 40.93 Kg/cm^2

Remark: - The average Compressive strength achieved is <u>16.95</u> % More than the specified value of 35 Kg/cm².

B) Water Absorption Test.

i) 11.35 %

ii) 9.89 %

iii) 11.11 %

Avg. 10.78 %

12.00 %

Remark: The average water absorption is 10.78 %, less than the maximum permissible limit of 12%.

To be used for – For side walls of nallah.

Copy to: 1. The Assistant Engineer, SDIII, WDVI, WRD, Mulgao – Goa.

- 2. Copy Submitted to The Superintending Engineer, CPO, WRD, Porvorim Goa for kind information.
- 3. Copy Submitted to The Executive Engineer, W.D. VI, WRD, Bicholim Goa.
- 4. Q.C. Lab file
- 5. Bill File.

Junior Engineer

Assistant Engineer