

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / TECH / WF.05-2022 / 18-A/2022-23.

Dated: **28-10-2022**

Name of the Work: Providing RCC slab over the drop of Sanvordem branch at Ch.700 m in Nirmala Nagar- Xeldem Village Quepem Taluka- Goa.

Sample Sent by: Assistant Engineer , SD I , WD XIV , WRD , Quepem- Goa.

Letter No: WRD / WD XIV/SD I/ W.F. /2022-23/125.

Dated:- 25-10-2022.

Received on: 25-10-2022

Date of Testing 27-10-2022

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.05/01/2022	Coarse Sand	FM Silt & Clay Grading	2.946 2.00% Zone II	2.3 to 3.1 Upto 5% I to III Zone	
F.05/03/2022	Aggregate-20 mm	Grading		As per IS-383:2016	To get the 20mm graded aggregate nominal size blend
F.05/04/2022	Aggregate- 10 mm	Grading		As per IS-383:2016	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD I, WD XIV, WRD Quepem- Goa.
- 2) The Executive Engineer, Works Division XIV, WRD, Rawanfond- Goa.
- 3) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
- 4) Office File.