

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection / Retaining wall to the nallah in Sy.No. 93/2 situated at Shirshirem in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.144/36/2021						240.00		No. WRD/WD XI/SD IV/
	F.144/37/2021	4/7/2022	1/8/2022	For Foundation	1.2.4	210 kg/cm2	235.56	235.56	F.460/171/2022-23
	F.144/38/2021						231.11		DATED:- 11-07-2022
1.2	F.144/39/2021						235.56		
	F.144/40/2021	4/7/2022	1/8/2022	For Foundation	1.2.4	210 kg/cm2	235.56	234.08	do
	F.144/41/2021						231.11		
2.1	F.144/42/2021						231.11		
	F.144/43/2021	5/7/2022	2/8/2022	For Foundation	1.2.4	210 kg/cm2	231.11	232.59	do
	F.144/44/2021						235.56		
2.2	F.144/45/2021						240.00		
	F.144/46/2021	5/7/2022	2/8/2022	For Foundation	1.2.4	210 kg/cm2	231.11	235.56	do
	F.144/47/2021						235.56		
3.1	F.144/48/2021						213.33		
	F.144/49/2021	6/7/2022	3/8/2022	Wall	1.2.4	210 kg/cm2	222.22	217.78	do
	F.144/50/2021						217.78		
3.2	F.144/50/2021						217.78		
	F.144/51/2021	6/7/2022	3/8/2022	Wall	1.2.4	210 kg/cm2	217.78	219.26	do
	F.144/52/2021						222.22		
4.1	F.144/53/2021						222.22		
	F.144/54/2021	7/7/2022	4/8/2022	Wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.144/55/2021						231.11		
4.2	F.144/56/2021						235.56		
	F.144/57/2021	7/7/2022	4/8/2022	Wall	1.2.4	210 kg/cm2	217.78	228.15	do
	F.144/58/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection / Retaining wall to the nallah in Sy.No. 93/2 situated at Shirshirem in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.144/59/2021						231.11		No. WRD/WD XI/SD IV/
	F.144/60/2021	9/7/2022	6/8/2022	Wall	1.2.4	210 kg/cm2	226.67	225.19	F.460/171/2022-23
	F.144/61/2021						217.78		DATED:- 11-07-2022
5.2	F.144/62/2021						222.22		
	F.144/63/2021	9/7/2022	6/8/2022	Wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.144/64/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER