

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 4646 & 4666/ Lab /97/ 2022 - 23 Dated:- 27/ 05/2022.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/Goa.

Name of work :Construction of Irrigation well in the field of Shri Sanjay Sadanand Tendulkar in Sy No. 3/4 in Village Codiem V.P. Pissurlem in Sattari Taluka.

Ref. to Requisition No.: MIN/WDVI/WRD/SDII/f-62/22-23/48 Dt.:- 29/ 04/ 2022

Qty. Recived. : 02 Sets of cube Date of Receipt:- 10/05/ 2022. Tested on: - 23 & 25/05/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample:Cube Mix RCC **1:1.5:3** O.SNo.:8604 & 8626/SS Lab. Sample No.: 4380 to 4381 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Valu e permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:1.5:3 , cast on 25/04/2022. RCC for Ring above bottom beam upto 3.00 mt. Height.	28 th day compressive strength	283.16	Kg/Cm ²	265.00 Kg/cm ²	10.27	Qty represents - 9.23 m3.
			294.48	Kg/Cm ²			
			299.01	Kg/Cm ²			
		Average	292.22	Kg/Cm²			
2	Cement concrete cube of mix 1:1.5:3 , cast on 27/04/2022. RCC for Ring from 3.50 mt to 7.50 mt. Height.	28 th day compressive strength	269.57	Kg/Cm ²	265.00 Kg/cm ²	4.57	Qty represents - 10.55 m3.
			283.16	Kg/Cm ²			
			278.63	Kg/Cm ²			
		Average	277.12	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SD II , WDVI , WRD,Valpoi-Sattari - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WD VI ,WRD, Bicholim - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer