GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 335 to 344 / Lab /171/ 2020 - 21 Dated: - 17 / 12 / 2020 Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of Anjuna Distributory taking off at ch. 28.97 km of the L.B.M.C. of T.I. P. in Siolim & Anjuna Village of Bardez Taluka. Part III: Construction of Rising main from Ch. 4.50 kms to Ch. 7.290 Kms, Break Pressure tank (BPT), Gravity main from Ch. 0.00 Kms to Ch. 1.00 Kms and reinstatement of allied structures for Anjuna Distributory in Siolim and Assagao Village of Bardez Taluka.

Ref. to Requisition No.: WRD /WD VIII / SD III / W F.32 /(PART -III)/2020-21/207 dated :-28 / 11 / 2020.

Qty. Recived.: 10 Sets of cube Date of Receipt:- 28 / 11 / 2020. Tested on: - 28/11/2020 To 01 /12/2020 Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:1.5:3 O.S No.: 4295, 4296, 4297, 4299, 4300, 4304, 4305, 4306, 4313 & 4314/SS. Lab. Sample No.: 9620 TO 9629

Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 02

SR.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:1.5:3 , cast on 31/10/2020, for 90 deg Thrust block at PHC. (S25)	28 th day	283.16	Kg/Cm ²	265.00 Kg/cm ²	6.85	Qty represents - 20.00 Cum.
		compressive	271.83	Kg/Cm ²			
		strength	294.48	Kg/Cm ²			
		Average	283.16	Kg/Cm ²			
2	Cement concrete cube of mix 1:1.5:3 , cast on 31/10/2020, for 90 deg Thrust block at PHC. (S26)	28 th day	276.36	Kg/Cm ²	265.00 Kg/cm ²	3.43	Qty represents - 21.00 Cum.
		compressive	287.69	Kg/Cm ²			
_		strength	258.24	Kg/Cm ²			
		Average	274.10	Kg/Cm ²			
	Cement concrete cube of mix 1:1.5:3 , cast on 31/10/2020, for 90 deg Thrust block at PHC. (S27)	28 th day	271.83	Kg/Cm ²	265.00 Kg/cm ²	3.72	Qty represents - 18.00 Cum.
3		compressive	262.77	Kg/Cm ²			
		strength	289.95	Kg/Cm ²			
		Average	274.85	Kg/Cm ²			
4		28 th day	274.10	Kg/Cm ²			
	Cement concrete cube of mix 1:1.5: 3 , cast on 01/11/2020, for 90 deg Thrust block at PHC. (S28)	compressive	294.48	Kg/Cm ²	265.00 Kg/cm ²	5.14	Qty represents - 18.00 Cum.
		strength	267.30	Kg/Cm ²			
		Average	278.63	Kg/Cm ²			

Junior Engineer

Assistant Engineer

REPORT PAGE 02 OF 02										
5	Cement concrete cube of mix 1:1.5:3, cast on 01/11/2020, for 90 deg Thrust block at PHC. (S29)	28 th day	276.36	Kg/Cm ²	265.00 Kg/cm ²	2.86	Qty represents - 13.00 Cum.			
		compressive	280.89	Kg/Cm ²						
		strength	260.51	Kg/Cm ²						
		Average	272.59	Kg/Cm ²						
	Cement concrete cube of mix 1:1.5:3, cast on 02/11/2020, for 90 deg Thrust block at Siolim market. (S30)	28 th day	296.75	Kg/Cm ²	265.00 Kg/cm ²	9.70	Qty represents - 17.00 Cum.			
6		compressive	283.16	Kg/Cm ²						
		strength	292.22	Kg/Cm ²						
		Average	290.71	Kg/Cm ²						
	Cement concrete cube of mix 1:1.5:3 , cast on 02/11/2020, for 90 deg Thrust block at Siolim market. (S31)	28 th day	265.04	Kg/Cm ²	265.00 Kg/cm ²	6.00	Qty represents - 20.00 Cum.			
-		compressive	289.95	Kg/Cm ²						
′		strength	287.69	Kg/Cm ²						
		Average	280.89	Kg/Cm ²						
	Cement concrete cube of mix 1:1.5:3 , cast on 02/11/2020, for 90 deg Thrust block at Siolim market. (S32)	28 th day	271.83	Kg/Cm ²		2.58	Qty represents - 19.00 Cum.			
0		compressive	262.77	Kg/Cm ²	265.00 Kg/cm ²					
٥		strength	280.89	Kg/Cm ²						
		Average	271.83	Kg/Cm ²						
	Cement concrete cube of mix 1:1.5:3 , cast on 03/11/2020, for 90 deg Thrust block at Siolim market. (S33)	28 th day	294.48	Kg/Cm ²	265.00 Kg/cm ²	6.00	Qty represents - 20.00 Cum.			
		compressive	267.30	Kg/Cm ²						
9		strength	280.89	Kg/Cm ²						
		Average	280.89	Kg/Cm ²						
	Cement concrete cube of mix 1:1.5:3, cast on 03/11/2020, for 90 deg Thrust block at Siolim market. (S34)	28 th day	292.22	Kg/Cm ²	265.00 Kg/cm ²		Qty represents - 14.00 Cum.			
10		compressive	278.63	Kg/Cm ²		4.29				
10		strength	258.24	Kg/Cm ²						
		Average	276.36	Kg/Cm ²						

Copy to: 1. The Assistant Engineer , SDIII , WD VIII, WRD, Karaswada, Bardez - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer ,WD VIII ,WRD, Karaswada -Bardez Goa.
- 4. QC Lab File. 5. Bill File.