

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 8545 / Lab / **400** / 2019 - 20 Dated:-22/ 01 / 2020
Laboratory : Bicholim - Goa. Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of Tivim Minor from ch. 2.290 Km To ch. 3.860 Km of L.B.M.C. of T.I.P. at Tivim Village in Bardez Taluka.

Ref. to Requisition No.: WRD /WD VIII / SD III / W F.51 /2019-20/224 dated :- 28 / 12 / 2019.

Qty. Recived. : 01 Set of cubes Date of Receipt:- 30/ 12 / 2019. Tested on: - 21 /01/2020 Ref to CPWD :2009, Vol. I

Sample: Cube Mix 1 : 1.5 : 3 O.S No. : 1554/AF. Lab. Sample No.: 7427 Tested By: Mr. Anil R. Fadte,. J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Reinforced Cement concrete cube of mix 1 : 1.5 : 3 , cast on 24/12/2019, RCC for Anchor block. (S1)	28 th day compressive strength	260.51	Kg/Cm ²	265.00 Kg/cm ²	2.58	Qty represents - 8.00 Cum.
			271.83	Kg/Cm ²			
			283.16	Kg/Cm ²			
		Average	271.83	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SDIII , WD VIII, WRD, Karaswada, Bardez - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer ,WD VIII ,WRD, Karaswada -Bardez - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer