

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 5465/ Lab /192/ 2022 - 23

Dated:- 14/11/2022.

Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of Piligao-Narva Distributory of LBMC of T.I.P. from Ch. 12.330 km to tail end at village Narva Mayem in Bicholim Taluka.

Ref. to Requisition No.: WRD/SDV/QC/WDVIII/F.W.3-9/2022-23/344(QC Programme) Dated :- 05/11/2022.

Qty. Received. : 01 Sets of cube Date of Receipt:- 05/11/2022. Tested on:- 12/11/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix **M25** O.S No. : 9470/SS. Lab. Sample No : 5371 Tested By: Mrs. S.B. Naik Shirodkar J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix M25 , cast on 05/11/2022 for the Slab @ RL 28.35m (Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers Shri Niranjan Pednekar, TA, SD IV , WD VIII, WRD and representative by agency M/s Laxmi Civil Engineering, Services Pvt. Ltd.	7 th day compressive strength	224.26	Kg/Cm ²	210.00 Kg/cm ²	5.35	28th day Test Due on 03/12/2022
			199.34	Kg/Cm ²			
			240.12	Kg/Cm ²			
		Average	221.24	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SD IV , WDVIII , WRD, Dodamarg - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WDVIII , WRD, Karaswada Bardez - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer