

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 5488/ Lab /201/ 2022 - 23 Dated:- 12/12/2022

Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of Piligao-Narva Distributory of LBMC of T.I.P. from Ch. 12.330 km to tail end at village Narva Mayem in Bicholim Taluka.

Ref. to Requisition No.: WRD/SDV/QC/WDVIII/F.W.3-9/2022-23/344(QC Programme) Dated :- 05/11/2022.

Qty. Received. : 01 Sets of cube Date of Receipt:- 05/11/2022. Tested on:- 03/12/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix **M25** O.S No. : 9501/SS. Lab. Sample No : 5371 Tested By: Mrs. S.B. Naik Shirodkar J.E.

REPORT PAGE 01 OF 01

| SR. NO. | DISCRIPTION OF SAMPLE | TESTED FOR | RESULTS | | Max./Min.Value permissable | % above or below | REMARK |
|---------|---|---|---------------|--------------------------|----------------------------|------------------|--------|
| | | | | | | | |
| 1 | Cement concrete cube of mix M25 , cast on 05/11/2022 for the Slab @ RL 28.35m (Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers Shri Niranjan Pednekar, TA, SD IV , WD VIII, WRD and representative by agency M/s Laxmi Civil Engineering, Services Pvt. Ltd. | 28 th day compressive strength | 283.16 | Kg/Cm ² | 290.00 Kg/cm ² | 2.07 | ----- |
| | | | 294.48 | Kg/Cm ² | | | |
| | | | 310.34 | Kg/Cm ² | | | |
| | | Average | 295.99 | Kg/Cm² | | | |

Copy to: 1. The Assistant Engineer , SD IV , WDVIII , WRD, Dodamarg - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WDVIII , WRD, Karaswada Bardez - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer