

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 5521/ Lab /213/ 2022 - 23

Dated:- 17/12/2022.

Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Strengthening and Renovation at existing bund from Nerul bridge to Caculo house at Candolim Bardez-Goa.

Ref. to Requisition No.: WRD/SDV/QC/WDVIII/F.W.3-9/2022-23/345(QC Programme) Dated :- 17/11/2022.

Qty. Recived. : 01 Sets of cube Date of Receipt:- 17/11/2022. Tested on:- 15/12/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix **1:2:4** O.S No. : 9569/SS. Lab. Sample No : 5396 Tested By: Mrs. S.B. Naik Shirodkar J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4 , cast on 17/11/2022 for the toe wall at ch.250.00m. (Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers Shri Sudesh Dessai, JE, SD II , WD I, WRD and representative by agency M/s Noor Engineering, PWD & Civil Contractors.	28 th day compressive strength	235.59	Kg/Cm ²	210.00 Kg/cm ²	5.71	-----
			210.67	Kg/Cm ²			
			219.73	Kg/Cm ²			
		Average	222.00	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SD II , WDI , WRD, Mapusa - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WDI , WRD, Porvorim - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer