

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 5594/ Lab /227/ 2022 - 23

Dated:- 03/01/2023.

Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of Protection wall on Valvanti river in property bearing Sy. No. 75/1, at Tulshima, Poriem in Sattari Taluka.

Ref. to Requisition No.: WRD/SDV/QC/WDVIII /F.3-9/2022-23/347 (QC Programme) Dated :- 24/12/2022.

Qty. Recived. : 01 Sets of cube Date of Receipt:- 24/12/2022. Tested on:- 31/12/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix **1:2:4** O.S No. : 9603/SS. Lab. Sample No : 5525 Tested By: Mrs. S.B. Naik Shirodkar J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4 , cast on 24/12/2022 for Pedestals.. (Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers Shri Anand Panchawadker, JE, SD IV , WD VI, WRD and Shri.Shivraj Rane representative by agency Jijabai Developers, H.No.107/5, Bharoniwada, Navelim, Sanquelim Goa.	7 th day compressive strength	174.43	Kg/Cm ²	140.00 Kg/cm ²	27.29	28th day Test Due on 21/01/2023
			181.22	Kg/Cm ²			
			178.96	Kg/Cm ²			
		Average	178.20	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SD IV , WDVI , WRD, Bicholim - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WDVI , WRD, Bicholim - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer