

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 2512/ Lab / **143** / 2021 - 22 Dated:- 08/07/2021. Laboratory : Bicholim - Goa
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of Open Type Bandhara across Bicholim river at Gaonkarwada at Bicholim.

Ref. to Requisition No.:WRD/ WDWI/SDI/F.W.220/2021-22/99 Dated :- 11/ 06/ 2021.

Qty. Recived. :01 Sets of cube Date of Receipt:- 11/ 06 / 2021. Tested on: -05/07/2021 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix RCC 1:1.5:3 O.S No.:6758/SS Lab. Sample No.: 1803 Tested By: Mrs. Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1 : 1.5: 3 , cast on 07/06/2021. RCC for Bandhara beam.	28 th day compressive strength	271.83	Kg/Cm ²	265.00 Kg/cm ²	2.86	Qty represents - 22.50 Cum.
			262.77	Kg/Cm ²			
			283.16	Kg/Cm ²			
		Average	272.59	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SD I , WD VI, WRD,Bicholim - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WD VI ,WRD, Bicholim- Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer