## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 10,000,022,048 & 064 / Lab / **66** / 2020 - 21

Dated: - 23 / 06 / 2020.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of Field Chnnels for DWC 1R takes off from Ch. 24.175 and DO 1R takes off from ch. 24.761 kms of LBMC of TIP at Colvale village of Bardez Taluka.

Ref. to Requisition No.: SD I / WD VIII /WRD / W. F.07 /2020-21/ **38** Dated :- 28 / 05 / 2020.

Qty. Recived.: 04 Sets of cube Date of Receipt:- 12 / 06 / 2020. Tested on: - 15/06/2020 To 20/06/2020, as per due dates. Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:2:4 O.S No.: 3911,3927,3949 & 3964/SS. Lab. Sample No.: 9213 To 9216 Tested By: Mrs. S. B. Naik Shirodkar. J.E.

## **REPORT PAGE 01 OF 01**

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4, cast on 18/05/2020. P.C.C. for beds of Chamber.	28 <sup>th</sup> day	237.85	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	5.71	Qty represents - 7.00 Cum.
		compressive	212.93	Kg/Cm <sup>2</sup>			
		strength	215.20	Kg/Cm <sup>2</sup>			
		Average	222.00	Kg/Cm <sup>2</sup>			
2	Cement concrete cube of mix <b>1:2:4</b> , cast on 20/05/2020. P.C.C. for beds of Chamber .	28 <sup>th</sup> day	226.53	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	16.50	Qty represents - 6.00 Cum.
		compressive	262.77	Kg/Cm <sup>2</sup>			
		strength	244.65	Kg/Cm <sup>2</sup>			
		Average	244.65	Kg/Cm <sup>2</sup>			
3	Cement concrete cube of mix <b>1:2:4</b> , cast on 22/05/2020. P.C.C. for wall Chamber .	28 <sup>th</sup> day	212.93	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	10.75	Qty represents - 6.00 Cum.
		compressive	249.18	Kg/Cm <sup>2</sup>			
		strength	235.59	Kg/Cm <sup>2</sup>			
		Average	232.57	Kg/Cm <sup>2</sup>			
4	Cement concrete cube of mix <b>1:2:4</b> , cast on 23/05/2020. P.C.C. for beds of Chamber .	28 <sup>th</sup> day	231.06	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>3</sup>	6.07	Qty represents - 7.00 Cum.
		compressive	226.53	Kg/Cm <sup>2</sup>			
		strength	210.67	Kg/Cm <sup>2</sup>			
		Average	222.75	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer, SD -I, WD VIII, WRD, Karaswada, Bardez - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer ,WD VIII ,WRD, Karaswada -Bardez Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer