

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No: WRD/QC/F.6-2/Cube -T : 6815/Lab/**39**/2023 - 24 Dated:- 02/05/2023.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of Open Type Bandhara near Gothneshwar temple at Bicholim in Bicholim Taluka.

Ref. to Requisition No : WRD/WDVI/SDI/F.W.220/2022-23/03 Dated :- 06/04/2023.

Qty. Recived : 01 Set of cube Date of Receipt:- 06/04/2023 Tested on:- 29/04/2023. Ref to CPWD :2009, Vol. I

Sample: Cube Mix **1:2:4** O.S No: 1149/RK Lab. Sample No : 6777. Tested By: Mrs. R.R. Kadam A.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4 , cast on 01/04/2023 PCC for Pier Foundation.	28 th day compressive strength	231.06	Kg/Cm ²	210.00 Kg/cm ²	7.15	Qty represents - 18.90 M3
			208.40	Kg/Cm ²			
			235.59	Kg/Cm ²			
		Average	225.02	Kg/Cm²			

Copy to: 1. The Assistant Engineer, SDI, WDVI, WRD, Bicholim - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WDVI, WRD, Bicholim - Goa.

4. QC Lab File. 5. Bill File.

Assistant Engineer