GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 8631,8632,8638,8639,8664,8665 / Lab / **423** / 2019 - 20 Dated: 03 / 02 / 2020 Laboratory : Bicholim - Goa. 8690,8691,8697 & 8698 Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of Work: - Improvement to Existing nallah along road side from Twenty Three Restaurant up to pond near starlight Restaurant at Village Arpora in Calangute Constituency.

Ref. to Requisition No.: SDII/WDI/WRD/ F.24 /2019-20/558 dated :-21/01/2020.

Qty. Recived.: 10 Sets of cube Date of Receipt: 23/01/2020. Tested on: 27/01/2020 To 03/02/2020. as per due dates. Ref to CPWD: 2009, Vol. I

Sample: Cube 1:2:4 Mix O.S No.: 3121,3122,3125,3126,3141,3142,3148,3149,3152,3153/SS Lab. Sample No.: 7701 to 7710 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 02

SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Plain Cement concrete cube of mix 1:2:4, cast on 30/12/2019.	28 th day	197.08	Kg/Cm2	210 kg/cm2	2.48	Quantity represented by each sample/ set of cube is not mentioned, and also exact location of work done is not specified.
		compressive	219.73	Kg/Cm2			
		strength	228.79	Kg/Cm2			
		Average	215.20	Kg/Cm2			
2	Plain Cement concrete cube of mix 1:2:4, cast on 30/12/2019.	28 th day	217.47	Kg/Cm2	- 210 kg/cm2	2.12	Do
		compressive	215.20	Kg/Cm2			
		strength	210.67	Kg/Cm2			
		Average	214.44	Kg/Cm2			
	Plain Cement concrete cube of mix 1:2:4, cast on 31/12/2019.	28 th day	208.40	Kg/Cm2	210 kg/cm2	6.43	Do
3		compressive	226.53	Kg/Cm2			
		strength	235.59	Kg/Cm2			
		Average	223.51	Kg/Cm2			
	Plain Cement concrete cube of mix 1:2:4, cast on 31/12/2019.	28 th day	215.20	Kg/Cm2	210 kg/cm2	4.27	Do
4		compressive	219.73	Kg/Cm2			
7		strength	222.00	Kg/Cm2			
		Average	218.98	Kg/Cm2			
	Plain Cement concrete cube of mix 1:2:4, cast on 02/01/2020.	28 th day	231.06	Kg/Cm2	210 kg/cm2	4.99	Do
5		compressive	226.53	Kg/Cm2			
		strength	203.87	Kg/Cm2			
		Average	220.49	Kg/Cm2			
6	Plain Cement concrete cube of mix 1:2:4, cast on 02/01/2020.	28 th day	233.32	Kg/Cm2	210 kg/cm2	12.54	Do
		compressive	262.77	Kg/Cm2			
		strength	212.93	Kg/Cm2			
		Average	236.34	Kg/Cm2			

REPORT PAGE 02 OF 02

SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
7	Plain Cement concrete cube of mix 1:2:4, cast on 04/01/2020.	28 th day	203.87	Kg/Cm2	210 kg/cm2	4.99	Quantity represented by each sample/ set of cube is not mentioned, and also exact location of work done is not specified.
		compressive	226.53	Kg/Cm2			
		strength	231.06	Kg/Cm2			
		Average	220.49	Kg/Cm2			
8	Plain Cement concrete cube of mix 1:2:4, cast on 04/01/2020.	28 th day	231.06	Kg/Cm2	- 210 kg/cm2	5.35	Do
		compressive	210.67	Kg/Cm2			
		strength	222.00	Kg/Cm2			
		Average	221.24	Kg/Cm2			
9	Plain Cement concrete cube of mix 1:2:4, cast on 06/01/2020.	28 th day	226.53	Kg/Cm2	- 210 kg/cm2	15.42	Do
		compressive	262.77	Kg/Cm2			
		strength	237.85	Kg/Cm2			
		Average	242.38	Kg/Cm2			
10	Plain Cement concrete cube of mix 1:2:4, cast on 06/01/2020.	28 th day	219.73	Kg/Cm2	- 210 kg/cm2	10.39	Do
		compressive strength	249.18	Kg/Cm2			
			226.53	Kg/Cm2			
		Average	231.81	Kg/Cm2			

Copy to: 1. The Assistant Engineer ,SD II,WD I,WRD, Mapusa - Goa.

- 2. Copy submitted to the Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to the Executive Engineer ,WD I,WRD, Porvorim Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer