GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD/QC/F. 6-2/Cube -T :- 7190,7216,7240/Lab/**100**/2023 - 24 Dated:- 17/06/2023.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work :- Construction of Open Type Bandhara across nallah at Bhatacho bandh Khotvaingan in Adwalpal village of Bicholim Taluka.

Ref. to Requisition No: F.36/SDIII/WDVI/WRD/2023-24/22 dated:-18/05/2023.

Oty. Recived.: **03** Sets of cubes Date of Receipt:- 08/06/2023 Tested on:- 09,12 & 14/06/2023 Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:1.5:3 & 1:2:4 O.S No: 1488,1514/RK & 863/SS . Lab. Sample No: 7427 To 7429 Tested By: Mrs. R.R. Kadam A.E. Mrs. S.B.Naik Shirodkar. J.E.

REPORT PAGE 01 OF 02

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:1.5:3 , cast on 12/05/2023. RCC for pier Foundation.	28 th day	280.89	Ka/Cm ²	265.00 Kg/cm ²	2.86	Qty represents - 18.00 cum.
		compressive	265.04	Ka/Cm ²			
		strength	271.83	Ka/Cm ²			
		A verage	272.59	Kg/Cm ²			
	Cement concrete cube of mix 1:2:4 , cast on 15/05/2023. PCC for d/s apron.	28 th day	224.26	Ka/Cm ²	210.00 Kg/cm ²	4.27	Qty represents - 19.00 cum.
		compressive	226.53	Ka/Cm ²			
		strength	206.14	Ka/Cm ²			
		A verage	218.98	Ka/Cm ²			
1 4	Cement concrete cube of mix 1:2:4 , cast on 17/05/2023. PCC for d/s & u/s apron.	28 th day	208.40	Ka/Cm ²	210.00 Kg/cm ²	5.35	Qty represents - 18.00 cum.
		compressive	217.47	Ka/Cm ²			
		strength	237.85	Ka/Cm ²			
		Average	221.24	Kg/Cm ²			

Copy to: 1. The Assistant Engineer, SDIII, WDVI, WRD, Mulgao - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WDVI, WRD, Bicholim Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer