## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD/QC/F. 6-2/Cube -T :- 7015,7016,7057,7058,7120,7121/Lab/**86**/2023 - 24 Dated:- 06/06/2023. Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work :- Construction of Raw Water Pumping Station at Amthane for Dhumacem water treatment Plant and Industrial Estate at Latambarcem.

Ref. to Requisition No: WRD/WDVI/SDI/F.W.74/2022-23/247 dated:-19/05/2023.

Oty. Recived.: **06** Sets of cubes Date of Receipt:- 20/05/2023 Tested on:- 25,30/05/2023 & 05/06/2023 Ref to CPWD: 2009, Vol. I

Sample: Cube Mix **1:1.5:3** O.S No: 1307,1308,1355,1356,1418,1419/RK. Lab. Sample No: 7153 To 7158 Tested By: Mrs. R.R. Kadam A.E.

## **REPORT PAGE 01 OF 02**

KEFOKT FAGE OF OLUZ												
SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or <del>below</del>	REMARK					
1	Cement concrete cube of mix <b>1:1.5:3</b> , cast on 27/04/2023. for Dam Top RCC. (12*5.40*0.25=16.20).	28 <sup>th</sup> day	246.91	Ka/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	8.85	Qty represents - 17.00 Cum.					
		compressive strength	308.08 310.34	Ka/Cm <sup>2</sup>								
		Average	288.44	Ka/Cm <sup>2</sup> Ka/Cm <sup>2</sup>								
2	Cement concrete cube of mix <b>1:1.5:3</b> , cast on 27/04/2023. for Dam Top RCC. (12*5.40*0.25=16.20).	28 <sup>th</sup> day	253.71	Ka/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	5.14	Qty represents - 17.00 Cum.					
		compressive	310.34	Ka/Cm <sup>2</sup>								
		strength	271.83	Ka/Cm <sup>2</sup>								
		Average	278.63	Ka/Cm <sup>2</sup>								
3	Cement concrete cube of mix <b>1:1.5:3</b> , cast on 02/05/2023. for Dam Top RCC. (12*5.40*0.25=16.20).	28 <sup>th</sup> day	262.77	Ka/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	5.43	Qty represents - 17.00 Cum.					
		compressive	283.16	Ka/Cm <sup>2</sup>								
		strength	292.22	Ka/Cm <sup>2</sup>								
		Average	279.38	Kg/Cm <sup>2</sup>								
4	Cement concrete cube of mix <b>1:1.5:3</b> , cast on 02/05/2023. for Dam Top RCC. (12*5.40*0.25=16.20).	28 <sup>th</sup> day	271.83	Ka/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	3.72	Qty represents - 17.00 Cum.					
		compressive	258.24	Ka/Cm <sup>2</sup>								
		strength	294.48	Ka/Cm <sup>2</sup>								
		Average	274.85	Ka/Cm <sup>2</sup>								

## **REPORT PAGE 02 OF 02**

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
5	Cement concrete cube of mix <b>1:1.5:3</b> , cast on 08/05/2023. for Dam Top RCC. (12*5.40*0.25=16.20).	28 <sup>th</sup> day	283.16	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	3.43	Qty represents - 17.00 Cum.
		compressive	262.77	Kg/Cm <sup>2</sup>			
		strength	276.36	Kg/Cm <sup>2</sup>			
		Average	274.10	Kg/Cm <sup>2</sup>			
6	Cement concrete cube of mix <b>1:1.5:3</b> , cast on 08/05/2023. for Dam Top RCC. (12*5.40*0.25=16.20).	28 <sup>th</sup> day	244.65	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	4.00	Qty represents - 17.00 Cum.
		compressive	289.95	Kg/Cm <sup>2</sup>			
		strength	292.22	Kg/Cm <sup>2</sup>			
		Average	275.61	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer, SDI, WDVI, WRD, Bicholim - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WDVI, WRD, Bicholim Goa.
- 4. QC Lab File. 5. Bill File.

**Assistant Engineer**