

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 2459,2464 / Lab /130/ 2021 - 22 Dated:-26/06/ 2021. Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work :Desilting of Rivulets /Poi, Agriculture fields and reconstruction of existing sluice in Savat Khazan and kharat khazan field at Shirgao in Bicholim Taluka.

Sub Est.IV:-Reconstruction of sluice (Near Mharingan Temple) in Kharat Khazan at Shirigao village in Bicholim Taluka.

Ref. to Requisition No.: F.36/SDIII/WDVI/WRD/2021-22/43 Dated :- 29/ 05/ 2021.

Qty. Received. :02 Sets of cube Date of Receipt:- 29/05/ 2021. Tested on: -22 & 24/06/2021 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC 1:2:4 O.S No. : 6700,6705/SS Lab. Sample No.: 1652 & 1653 Tested By: Mrs. Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4 , cast on 25/05/2021. P.C.C. for LHS Abutment of retaining wall.	28 th day compressive strength	244.65	Kg/Cm ²	210.00 Kg/cm ²	13.26	Qty represents -17.00 Cum.
			237.85	Kg/Cm ²			
			231.06	Kg/Cm ²			
		Average	237.85	Kg/Cm²			
2	Cement concrete cube of mix 1:2:4 , cast on 27/05/2021. P.C.C. for LHS Abutment of retaining wall.	28 th day compressive strength	215.20	Kg/Cm ²	210.00 Kg/cm ²	5.35	Qty represents -16.00 Cum.
			228.79	Kg/Cm ²			
			219.73	Kg/Cm ²			
		Average	221.24	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SD III , WD VI, WRD,Mulgao - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WD VI ,WRD, Bicholim - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer