GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 2483,2495,2509,2526,2549,2590/ Lab / **165** / 2021 - 22 Dated:-27/07/2021. Laboratory : Bicholim - Goa. 2615,2622,2631 Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of Anjuna Distributory taking off at ch.28.970km of the left Bank Main canal of Tillari irrigation Project in Siolim & Anjuna village of Bardez Taluka.part III:construction of Rising Main from ch.4.50. kms to ch.7.290 kms, Break Pressure tank (BPT), Gravity main from ch0.00m kms and reinstatement of allied structures of Anjuna Distributory in Siolim and Assagao village of Bardez Taluka

Ref. to Requisition No.: SDIII/WDVIII/WRD/WF.32(PART-III)/21-22/86 Dated: 01/07/2021.

Qty. Recived.: 09 Sets of cube Date of Receipt:- 02/07/2021. Tested on: 02,03,05,07,09,13,16,19,24/07/2021 as per due dates. Ref to CPWD: 2009, Vol. I Sample: Cube Mix 1: 2: 4 O.S No.: 6725,6767,6755,6774,6797,6839/SS,88/RK,6860,6869/SS. Lab. Sample No.: 2031 To 2039 Tested By: Mrs.R.R.Kadam A.E & Mrs. Shirodkar. J.E.

REPORT PAGE 01 OF 02

	REPORT PAGE 01 OF 02												
SR.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value	% above or	REMARK						
NO	DISCRIPTION OF SAIVIFLE	TESTED FOR			permissable	below	KEIVIAKK						
	Cement concrete cube of mix 1:2:4, cast on 04/06/2021. For Road side gutter at Assagao EP-LT-172-39/35.	28 th day	242.38	Kg/Cm ²	210.00 Kg/cm ²	9.67	Qty represents - 18.00 Cum.						
		compressive	217.47	Kg/Cm ²									
		strength	231.06	Kg/Cm ²									
		Average	230.30	Kg/Cm ²									
	Cement concrete cube of mix 1:2:4 , cast on 05/06/2021. For Road side gutter at Assagao EP-LT-172-39/35.	28 th day	237.85	Kg/Cm ²	210.00 Kg/cm ²	8.59	Oty represents - 17.00 Cum.						
		compressive	231.06	Kg/Cm ²									
		strenath	215.20	Kg/Cm ²									
		Average	228.04	Kg/Cm ²									
	Cement concrete cube of mix 1:2:4 , cast on 07/06/2021. For Road side gutter at Assagao EP-LT-172-39/35.	28 th day	226.53	Kg/Cm ²	210.00 Kg/cm ²	11.82	Oty represents - 13.00 Cum.						
		compressive	228.79	Kg/Cm ²									
		strenath	249.18	Kg/Cm ²									
		Average	234.83	Kg/Cm ²									
	Cement concrete cube of mix 1:2:4 , cast on 09/06/2021. For Road side gutter at Assagao at Ganesh Temple.	28 th day	237.85	Kg/Cm ²	210.00 Kg/cm ²	8.59	Qty represents - 19.00 Cum.						
		compressive	212.93	Kg/Cm ²									
		strength	233.32	Kg/Cm ²									
		Average	228.04	Kg/Cm ²									
	Cement concrete cube of mix 1:2:4 , cast on 11/06/2021. For Road side gutter at Assagao EP-LT-172-39/48.	28 th day	226.53	Kg/Cm ²	210.00 Kg/cm ²	9.31	Oty represents - 12.00 Cum.						
		compressive	244.65	Kg/Cm ²									
		strenath	217.47	Kg/Cm ²									
		Average	229.55	Kg/Cm ²									

REPORT PAGE 02 OF 02

SR. NO	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
	Cement concrete cube of mix 1:2:4 , cast on 15/06/2021. For Road side gutter at Sonarkhed EP-LT-173-39/26.	28 th day	244.65	Kg/Cm ²	210.00 Kg/cm ²	12.18	Qty represents - 20.50 Cum.
6		compressive	226.53	Kg/Cm ²			
_		strenath	235.59	Kg/Cm ²			
		Average	235.59	Kg/Cm ²			
	Cement concrete cube of mix 1:2:4 , cast on 18/06/2021. For Road side gutter at Sonarkhed EP-LT-173-39/13.	28 th day	215.20	Kg/Cm ²	210.00 Kg/cm ²	8.59	Qty represents - 10.00 Cum.
7		compressive	231.06	Kg/Cm ²			
′		strength	237.85	Kg/Cm ²			
		Average	228.04	Kg/Cm ²			
	Cement concrete cube of mix 1:2:4 , cast on 21/06/2021. For Road side gutter at Sonarkhed EP-LT-173-39/15.	28 th day	228.79	Kg/Cm ²	210.00 Kg/cm ²	9.67	Oty represents - 9.00 Cum.
		compressive	235.59	Kg/Cm ²			
		strenath	226.53	Kg/Cm ²			
		Average	230.30	Kg/Cm ²			
	Cement concrete cube of mix 1:2:4 , cast on 26/06/2021. For Road side gutter at Sonarkhed EP-LT-173-39/18.	28 th day	201.61	Kg/Cm ²	210.00 Kg/cm ²	6.79	Qty represents - 11.00 Cum.
		compressive	226.53	Kg/Cm ²			
		strenath	244.65	Kg/Cm ²			
		Average	224.26	Kg/Cm ²			

Copy to: 1. The Assistant Engineer , SD III , WDVIII , WRD-Karaswada-Bardez - Goa.

Junior Engineer

Assistant Engineer

^{2.} Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

^{3.} Copy submitted to The Executive Engineer , WD VIII ,WRD, Karaswada-Bardez- Goa.

^{4.} QC Lab File. 5. Bill File.